

مصنع شاطئ البحر للكابلات

# SEASHORE CABLES FACTORY

A Direct Subsidiary of Seashore Group

## CONSULTANTS APPROVALS



+974 44888499 | P.O. Box: 41100, Zone 81, Building 161, Street 24, New Industrial Area, Doha, Qatar

info@seashorecables.com | www.seashorecables.com

## INDEX

SL NO	PROJECT DETAILS	
1	Project Name Client Name Project Consultant Project Contractor Project Sub Contractor Approved Materials	NORTH FIELD EXPANSION PROJECT. NFS-CLLNG- BOP Qatar energy LNG Qatar energy LNG Tecnicas Reunidas S.A. Como Electrical Wires
2	Project Name Client Name Project Consultant Project Contractor Project Sub Contractor Approved Materials	RLTO EXPANSION AND OFFPLOT FACILITIES OF THE NORTH FIELD EXPANSION PROJECT (EPC-3) Qatar Gas Operating Company Limited Qatar Gas Operating Company Limited Tecnicas Reunidas S.A. China Eleventh Chemical Construction Electrical Wires
3	Project Name Client Name Project Consultant Project Contractor Project Sub Contractor Approved Materials	PROPOSED 10 VILLAS COMPOUND Mr. Jaber A.Khamis Al-Sulaiti Eng. Adnan Saffarini Thamco Al Tahrir Trading & Contracting For Electro Mechanical Works Electrical Wires
4	Project Name Client Name Project Consultant Project Contractor Approved Materials	THE CONSTRUCTION, COMPLETION AND MAINTENANCE OF MADINAT AL MAWATER PHASE 3 Barwa Group CEG International Hassanesco Trading & Contracting Single Core Wires & Flexible cables
5	Project Name Client Name Project Consultant Project Contractor Approved Materials	FOOD STORAGE AREA (G), ACCOMMODATION (G+2), ADMIN & SHOWROOM (G+1) High Record Project United Architects GTTC Single Core Wires



SL NO	PROJECT DETAILS	
6	Project Name	SPLASH AT CITY CENTER
	Client Name	Landmark Retail
	Project Consultant	Qatar Design consortium
	Project Contractor	Mechon Trading & Contracting
	Project Sub Contractor	Green Square Trading & Contracting
	Approved Materials	Heat Resistant Flexible Cables
7	Project Name	FLORESTA GARDENS - 107 & 108
	Client Name	Al Mana Capital Real Estate
	Project Consultant	Design Supervision Group Architectural & Engineering Consultancy W.L.L
	Project Contractor	Al Seal contracting & Trading Company
	Approved Materials	Single Core Wires & Multi Core Flexible Cables
8	Project Name	DESIGN & CONSTRUCTION OF THE NED DOHA - RENOVATION OF FORMER MINISTRY OF INTERIOR BUILDING
	Client Name	Oryx Corniche Developments QP JSC / Soho House & Co
	Project Consultant	Ehaf Qatar
	Project Contractor	Urbacon Trading & Contracting
	Project Sub Contractor	Elegancia MEP
	Approved Materials	Single Core Wires
9	Project Name	ARIANE CITY PHASE 2 (5 NEW BUILDINGS)
	Client Name	Ariane Real Estate
	Project Consultant	Conseil Engineering Consultancy
	Project Contractor	K.B.R
	Approved Materials	Single Core Wires
10	Project Name	ARIANE PROJECT PHASE 2 (12 RESIDENTIAL BUILDING B+G+5 TYPICAL) @ MESAIMEER
	Client Name	Ariane Real Estate
	Project Consultant	Conseil Engineering Consultancy
	Project Contractor	Construction Engineering Contracting (CEC)
	Approved Materials	Single Core Wires
11	Project Name	PALACE HOTEL & SPA
	Client Name	Asset Real Estate Development Co. W.I.I.
	Project Consultant	GHD
	Project Contractor	Urbacon Trading & Contracting
	Project Sub Contractor	Elegancia Electro Mechanical
	Approved Materials	Single Core Wires

SL NO	PROJECT DETAILS	
12	Project Name Client Name Project Consultant Project Contractor Approved Materials	THE QATAR SCHOOLS PPP DEVELOPMENT PROGRAM - PACKAGE 1 Public Works Authority (ASHGHAL) AEB - Arab Engineering Bureau JTC - Al Jaber Trading & Contracting Co. Single Core Wires
13	Project Name Client Name Project Consultant Project Contractor Approved Materials	FITOUT AT MINISTRY OF MUNICIPALITY AND ENVIRONMENT P2 EXTENSION @ WESTBAY Public Works Authority (ASHGHAL) Al Kashaf International Salam Industries Single Core Wires
14	Project Name Client Name Project Consultant Project Contractor Approved Materials	FLORESTA GARDENS FG - 102 - 110, THE PEARL QATAR Al Mirqab Real Estate Development & Investment Company Design Supervision Group Architectural & Engineering Consultancy W.L.L Al Seal contracting & Trading Company Single Core Wires
15	Project Name Client Name Project Consultant Project Contractor Project Sub Contractor Approved Materials	PROPOSED PALACE (B+G+1+ROOF) + MAJILES + OUTDOOR BLOCK 01 + BLOCK 02 M/s Shiekh Essa Hamad J T Al - Thani United Architects Al Gharafa Trading and Contracting Elite Prime ElectroMechanical Services Single Core Wires
16	Project Name Client Name Project Consultant Project Contractor Approved Materials	DEIGN AND BUILD OF GRANDSTAND IN AL-UQDA EQUESTRIAN COMPLEX Public Works Authority (ASHGHAL) EGEC Qatar for Engineering Consultation BrickStone Trading and Contracting Building Wire & Flexible Cables
17	Project Name Client Name Project Consultant Project Contractor Project MEP Contracto Approved Materials	CONSTRUCTION OF SATELLITE MONITORING SYSTEM Public Works Authority (ASHGHAL) Gulf Consulting Group BrickStone Trading and Contracting Q-TEC Engineering Flexible Cables



SL NO	PROJECT DETAILS	
18	Project Name Client Name Project Consultant Project Contractor Approved Materials	G + 1 AL KHEESA SOUQ (CENTRO MALL) M.H.Al Mana Group Design Supervision Group Architectural & Engineering Consultancy W.L.L Advanced Engineering and Maintenance Company Flexible Cables
19	Project Name Client Name Project Consultant Project Contractor Project Sub Contractor Approved Materials	MODIFICATION OF EXISTING(G +4) BUILDING © AT AL AHLI HOSPITAL, BIN OMRAN Al Ahli Hospital United Architects Al Masaken Elite Prime ElectroMechanical Services Electrical Wires
20	Project Name Client Name Project Consultant Project Contractor Approved Materials	AL YASMEEN CITY - ALWADI 2 Sigma Contracting and Trading Conseil Engineering Consultancy Sigma Contracting and Trading Single Core Wires
21	Project Name Client Name Project Consultant Project Contractor Approved Materials	AL WAAB CITY CENTRAL DISTRICT PHASE 1 PACKAGE 4 (PARCEL 1 & 2) Al Waab City CEG International MEKDAM Technology Heat Resistant Flexible Cables
22	Project Name Client Name Project Consultant Project Contractor Approved Materials	FITOUT AT CBQ CBFS D-RING MEZZANINE BRANCH Commercial Bank of Qatar Al Kashaf International Salam Industries Single Core Wires
23	Project Name Client Name Project Consultant Project Contractor Approved Materials	1023-4 GIARDINO VILLAGE 22 RESIDENTIAL VILLA (G+2+PH), THE PEARL Mr. Hamad Ali Hamad Alramoul Almannai Trust Engineering Consultancy Pride Projects W.L.L. Single Core Wires



SL NO	PROJECT DETAILS	
24	Project Name Client Name Project Consultant Project Contractor Approved Materials	RESIDENTIAL & COMMERCIAL BUILDING (B+G+5) @ AL WAAB Abk For Projects & Developments Eng. Adnan Saffarini Office Abk For Projects & Development Flexible Cables
25	Project Name Client Name Project Consultant Project Contractor Approved Materials	1099-PROPOSED MOSQUE & IMAM HOUSE IN UM AL SANEEM AWQAF Ministry Of Endowments & Islamic Affairs Turnkey Trading & contracting Single Core Wires & Flexible Cables
26	Project Name Client Name Project Consultant Project Contractor Approved Materials	754-CONSTRUCTION MOSQUE & IMAM HOUSE IN AL EBB AWQAF Ministry Of Endowments & Islamic Affairs Turnkey Trading & contracting Single Core Wires & Flexible Cables
27	Project Name Client Name Project Consultant Project Contractor Approved Materials	PRIVATE VILLA (G+1+STAIRS) SERVICES BLOCKS & GUARD ROOM AND OUTDOOR SWIMMING POOL IN AL WUKAIR ON PLOT NO. 91012492 Shk Mohamed AbdulRahman J A Al-Thani LACASA architects & engineering consultants UrbaCon Trading and contracting Heat Resistant Flexible Cables
28	Project Name Client Name Project Consultant Project Contractor Approved Materials	979-2 FITOUT, BUROOK TOWER DAFNA Shiekh Nayf Suhaim H A Al-Thani Trust Engineering Consultancy Spacedge Decoration Single Core Wires
29	Project Name Client Name Project Consultant Project Contractor Project Sub Contractor Approved Materials	GV 60 & GV 61 (B+G+1+PH) GIARDINO VILLAGE THE PEARL Danat Qatar HTCO – Hany Tawfik Consulting Office Pride Projects JMT Contracting Single Core Wires



# MATERIAL APPROVAL REQUEST

No.: 10370-CON-GEN-30  
Rev.: 1  
Date: 10 May-2023  
Page: 1 of 1

PROJECT: NORTH FIELD EXPANSION PROJECT .NFS-CLLNG-BOP	CONTRACTOR/SUBCONTRACTOR:COMO W.L.L	QR CODE
AREA / UNIT / SYSTEM / SUBSYSTEM:TCF BUILDINGS	ITP/ACTIVITY No.:NFXP3-TRSA-QM-ITP-01001	
ELEMENT / TAG No.: N/A	INSPECTION TYPE CONTRACTOR/COMPANY:	
TEST PACKAGE:N/A	REPORT No. / RFI:NFXP3-COQ-EL-MAR-00020	

This certificate does not exempt the Subcontractor from the Terms of the Contract, Project Specifications or Quality Procedures but confirms that all these Tests have been performed according to them.

DISCIPLINE							
	CIVIL		BUILDING FINISHING		PIPING		INSTRUMENTATION
	STRUCTURAL		MECHANICAL	✓	ELECTRICAL		OTHERS:_____

We request approval to the following material:

MATERIAL DESCRIPTION	MATERIAL SPECIFICATION	MATERIAL TO BE USED FOR	SUPPLIER / MANUFACTURER / VENDOR	SUPPLIER / MANUFACTURER / VENDOR LOCATION
CABLES & WIRES	301-91-EL-SPC-00014 &301-91-EL-SPC-00011	TCF BUILDINGS	SEASHORE CABLE FACTORY	QATAR

This material complies with Project Specification:  YES : REF -301-00-EL-SPC-00014 & 301-00-EL-SPC-00011  NO : Comments \_\_\_\_\_

Manufacturer/Supplier included in PVL:  YES :  NO : Comments: Previous project approval attached

REFERENCE DRAWING: NFXP3-COQ-EL-DWG-00022,NFXP3-COQ-EL-DWG-00091,NFXP3-COQ-EL-DWG-00025,NFXP3-COQ-EL-DWG-00093,NFXP3-COQ-EL-DWG-00094,NFXP3-COQ-EL-DWG-00028,NFXP3-COQ-EL-DWG-00088,NFXP3-COQ-EL-DWG-00089,NFXP3-COQ-EL-DWG-00031,NFXP3-COQ-EL-DWG-00034,NFXP3-COQ-EL-DWG-00040

DOCUMENTS ATTACHED: PROJECT SPECIFICATION,COMPLIANCE STATEMENT,DATA SHEET,TEST REPORT,PREVIOUS APPROVAL  
DRAWINGS,COMPANY PROFILES & ISO CERTIFICATES

**NOTE:** The documents have been reviewed to general conformance with the contract. Such review does not relieve the subcontractor of his responsibilities under the item of the contract nor authorize to waive any contractual requirements.

- ACCEPTED
- ACCEPTED WITH COMMENTS
- REJECTED
- REVISE AND RESUBMIT

REMARKS:

Applicable Drawings:

		CONFIRMED				
WITNESSED/ REVIEWED BY:	SUBCONTRACTOR QUALITY	CONTRACTOR CONSTRUCTION	CONTRACTOR QUALITY	Requested by Quality	YES <input type="checkbox"/> NO <input type="checkbox"/>	COMPANY
				CONTRACTOR ENGINEERING		
SIGNATURE:						
PRINT NAME:						
DATE:						

COMPANY: QATARENERGY LNG	Contract No.: LTC/C/NFE/3998/18 (NFX-EPC3-QGC-TRS-CHO-00033)
PROJECT: RLTO EXPANSION AND OFFPLOT FACILITIES OF THE NORTH FIELD EXPANSION PROJECT (EPC-3) – NFS CLLNG BOP PROJECT	Doc. No.: NFXP3-COQ-EL-MAR-00020
CONTRACTOR: TECNICAS REUNIDAS S.A. SUBCONTRACTOR: COMO W.L.L	Rev. B
<b>Doc. Title: MATERIAL APPROVAL REQUEST FOR CABLES AND WIRES FOR BUILDINGS (TCF –BOP CAMP) (SOURCE: SEASHORE CABLE FACTORY)</b>	

**CONTRACT TITLE :**  
**ENGINEERING, PROCUREMENT, CONSTRUCTION AND COMMISSIONING AGREEMENT FOR RLTO EXPANSION AND OFF PLOT FACILITIES OF THE NORTH FIELD EXPANSION PROJECT**

**TITLE:**  
**MATERIAL APPROVAL REQUEST FOR CABLES AND WIRES FOR BUILDINGS (TCF –BOP CAMP)  
(SOURCE: SEASHORE CABLE FACTORY)**

B	22-Oct-2024	Issued for Approval	PK				
A	25-Aug-2024	Issued for Inter-Discipline Check	PK				
Rev.	Issue Date	Revision Description	Prep'd by CONT.	Chk'd by CONT.	App'd by CONT.	Chk'd by COMPANY	App'd by COMPANY

**COMPANY**

	<b>QATAR ENERGY LNG</b>
---	-------------------------

**CONTRACTOR**

	<b>TECNICAS REUNIDAS S.A.</b>
---	-------------------------------

**SUBCONTRACTOR**

	<b>COMO W.L.L</b>
---	-------------------

DOCUMENT NO.	<b>NFXP3-COQ-EL-MAR-00020</b>	DOC. CLASS	1
--------------	-------------------------------	------------	---

COMPANY: QATARENERGY LNG	Contract No.: LTC/C/NFE/3998/18 (NFX-EPC3-QGC-TRS-CHO-00033)
PROJECT: RLTO EXPANSION AND OFFPLOT FACILITIES OF THE NORTH FIELD EXPANSION PROJECT (EPC-3) – NFS CLLNG BOP PROJECT	Doc. No.: NFXP3-COQ-EL-MAR-00020
CONTRACTOR: TECNICAS REUNIDAS S.A. SUBCONTRACTOR: COMO W.L.L	Rev. B
<b>Doc. Title: MATERIAL APPROVAL REQUEST FOR CABLES AND WIRES FOR BUILDINGS (TCF –BOP CAMP) (SOURCE: SEASHORE CABLE FACTORY)</b>	

## PREVIOUS PROJECT APPROVALS



## Company Comments Review Summary

PROJECT ID	NFXP3	ORIGINATOR CODE	ECC			
Reference	Rev.	Rev. Date	St.	Class	Discipline	Doc Type
NFXP3-ECC-EL-MAR-00005	02	2024-02-12	AFC	1	EL	MAR

### Review Details:

Previous Rev. Return Code: B-Approved/Reviewed with minor comments

Document received with Transmittal IN: NFXP3-T-TRSA-QG-74172

Receipt Date: 2024-02-12

The Document Review has been initiated on: 2024-02-13

Review Time Frame: 14 day(s)

Role	Name	Return Code	Date of Comment
approver	Christopher James Bonner (21715)	A-Approved/Reviewed with no comments	2024-02-18

If applicable as per Approver return code, comments are available either after this page and/or as external attached comments below.

Number of annotation(s): 0

This page is automatically generated from PIMS and shall be considered as official answer from COMPANY.

 		<b>RLTO EXPANSION AND OFFPLOT FACILITIES OF THE NORTH FIELD EXPANSION PROJECT (EPC-3)</b>		
<b>CONTRACTOR Doc. Code:</b> PRC-0057	<b>CONTRACTOR DOC. NO.:</b> NFXP3-ECC-EL-MAR-00005	<b>REV</b> 2	<b>CONTRACTOR PROJECT No.</b> 10370	<b>PROJECT CONTRACT No.</b> LTC/C/NFE/3998/18
<b>SUBCONTRACTOR NAME &amp; LOGO</b> CHINA ELEVENTH CHEMICAL CONSTRUCTION W.L.L (ELECO)				<b>SUBCONTRACTOR NO.:</b> 1037025010
<b>DOCUMENT TITLE:</b> MATERIAL APPROVAL REQUEST FOR ELECTRICAL MATERIALS FOR CAMP ACCOMMODATION PORTACABIN BUILDINGS IN EPC 3				
<b>SUBCONTRACTOR DOCUMENT NO.:</b> NFXP3-ECC-EL-MAR-00005			<b>SUBCONTRACTOR REV:</b> 2	
<b>COMPANY DOCUMENT NO.:</b> NFXP3-ECC-EL-MAR-00005		<b>COMPANY REV</b> 2	<b>DOC. CLASS</b> 1	
<b>REVIEW RESPONSE BY CONTRACTOR:</b> CONTRACTOR REVIEW COMMENTS DO NOT INDICATE EITHER RESPONSIBILITY OR LIABILITY FOR ACCURACY AND COMPLETENESS OF THIS DOCUMENT OR ALTER ANY CONTRACTUAL TERMS AND CONDITIONS.				
<input type="checkbox"/> A - REJECTED <input type="checkbox"/> C - REVIEWED WITH MINOR COMMENTS <input checked="" type="checkbox"/> F - REVIEWED WITHOUT COMMENTS  <input type="checkbox"/> B - REVIEWED WITH MAJOR COMMENTS <input type="checkbox"/> R - AS BUILT <input type="checkbox"/> I - FOR INFORMATION				
DATE: <b>12.FEB.2024</b>				



COMPANY: QATARGAS OPERATING COMPANY LIMITED	Contract No.: LTC/C/NFE/3998/18
PROJECT: RLTO EXPANSION AND OFFPLOT FACILITIES OF THE NORTH FIELD EXPANSION PROJECT (EPC-3)	Doc. No.: <b>NFXP3-ECC-EL-MAR-00005</b>
CONTRACTOR: TECNICAS REUNIDAS S.A. SUBCONTRACTOR: CHINA ELEVENTH CHEMICAL CONSTRUCTION WLL	Rev.2 Page 1 of 256
DOC TITLE: MATERIAL APPROVAL REQUEST FOR ELECTRICAL MATERIALS FOR CAMP ACCOMMODATION PORTACABIN BUILDINGS IN EPC-3	

**CONTRACT TITLE:**

**AGREEMENT FOR RLTO EXPANSION AND OFF PLOT FACILITIES OF THE NORTH  
FIELD EXPANSION PROJECT ENGINEERING, PROCUREMENT,  
CONSTRUCTION AND COMMISSIONING**

**DOCUMENT TITLE:**

**MATERIAL APPROVAL REQUEST FOR ~~E~~ELECTRICAL MATERIALS FOR CAMP  
ACCOMMODATION PORTACABIN BUILDINGS IN EPC 3**

							
2	04-Feb-2024	Approved For Construction	Dinesh	Gopal Ch Das	Yang Yong		
1	11-Jan-2024	Approved For Construction	Dinesh	Gopal Ch Das	Yang Yong		
0	18-Jul-2023	Approved For Construction	RAJARAJAN	GopalCh Das	Yang Yong		
B	08-Jun-2023	Issued For Approval	RAJARAJAN	GopalCh Das	Yang Yong		
A	29-May-2023	Issued for Inter-Discipline Check	RAJARAJAN	Gopal Ch Das	Yang Yong		
Rev.	Issue Date	Revision Description	Prep'd by SUBCONT.	Chk'd by SUBCONT.	App'd by SUBCONT.	Chk'd by COMPANY.	App'd by COMPANY.

**COMPANY****QATARGAS OPERATING COMPANY LIMITED****CONTRACTOR****TECNICAS REUNIDAS S.A.****SUBCONTRACTOR****CHINA ELEVENTH CHEMICAL CONSTRUCTION W.L. L**

DOCUMENT NO.

NFXP3-ECC-EL-MAR-00005

DOC. CLASS

1

 	<h2 style="margin:0;">MATERIAL APPROVAL REQUEST</h2>	No.: 10370-CON-GEN-30 Rev.: 1 Date: 10-MAY-2023 Page: 1 of 1
---	--	---

<b>PROJECT:</b> NFE EXPANSION PROJECT EPC-3 <b>AREA / UNIT / SYSTEM / SUBSYSTEM:</b> Rito Expansion and off plot facilities of the north field Expansion project (EPC-3) <b>ELEMENT / TAG No.:</b> N/A <b>TEST PACKAGE:</b> N/A	<b>CONTRACTOR/SUBCONTRACTOR:</b> CHINA ELEVENTH CONSTRUCTION COMPANY <b>ITP/ACTIVITY No.:</b> N/A <b>INSPECTION TYPE CONTRACTOR/COMPANY:</b> <b>REPORT No. / RFI:</b> NFXP3 - ECC-EL-MAR-00005	<b>QR CODE</b>
--	---	----------------

This certificate does not exempt the Subcontractor from the Terms of the Contract, Project Specifications or Quality Procedures but confirms that all these Tests have been performed according to them.

DISCIPLINE							
	CIVIL		BUILDING FINISHING		PIPING		INSTRUMENTATION
	STRUCTURAL		MECHANICAL	X	ELECTRICAL		OTHERS: _____

**We request approval to the following material:**

MATERIAL DESCRIPTION	MATERIAL SPECIFICATION	MATERIAL TO BE USED FOR	SUPPLIER / MANUFACTURER / VENDOR	SUPPLIER / MANUFACTURER / VENDOR LOCATION
LIGHTING FIXTURE - LED SURFACE MOUNTED	301-91-EL-SPC-00014	PORTACABIN BUILDING	ANHUI SHINGEL LIGHTING TECHNOLOGY Co. Ltd.	CHINA
SWITCHES & SOCKETS	301-91-EL-SPC-00014	PORTACABIN BUILDING	TENBY	UAE
DB & BREAKERS	301-91-EL-SPC-00014	PORTACABIN BUILDING	HAGER	CHINA
WIRE	301-91-EL-SPC-00014	PORTACABIN BUILDING	SEASHORE CABLES FACTORY	QATAR
WIRE		PORTACABIN BUILDING	QICC - NEXANS	
WIRE	301-91-EL-SPC-00014	PORTACABIN BUILDING	NUHAS OMAN L.L.C.	OMAN
WIRE	301-91-EL-SPC-00014	PORTACABIN BUILDING	DOHA CABLES	QATAR
EMERGENCY LIGHT	301-91-EL-SPC-00014	PORTACABIN BUILDING	ANHUI SHINGEL LIGHTING TECHNOLOGY Co. Ltd.	CHINA
EMERGENCY LIGHT CONVERTER & BATTERY	301-91-EL-SPC-00014	PORTACABIN BUILDING	EFFORT	CHINA

This material complies with Project Specification:  YES : Reference 301-00-ST-SPC-00014  NO : Comments \_\_\_\_\_

Manufacturer/Supplier included in PVL:  YES : Reference DE892162 -BF13-4793  NO : Comments\_Previous Approvals attached

REFERENCE DRAWING:



DOCUMENTS ATTACHED:

**NOTE:** The documents have been reviewed to general conformance with the contract. Such review does not relieve the subcontractor of his responsibilities under the item of the contract nor authorize to waive any contractual requirements.

- ACCEPTED
- ACCEPTED WITH COMMENTS
- REJECTED
- REVISE AND RESUBMIT



**REMARKS:**

**Applicable Drawings:**

WITNESSED/ REVIEWED BY:	SUBCONTRACTOR QUALITY	CONTRACTOR CONSTRUCTION	CONFIRMED		COMPANY
			Requested by Quality	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	
SIGNATURE:					Code A- Approved/Reviewed with no comments
PRINT NAME:	RAJARAJAN	Jordan Evangelista	Bipin Palrose	Christopher James Bond	
DATE:	04-Feb-24	12-FEB-2024	07-Feb-2024	18-Feb-2024	

 		<b>RLTO EXPANSION AND OFFPLOT FACILITIES OF THE NORTH FIELD EXPANSION PROJECT (EPC-3)</b>		
<b>CONTRACTOR Doc. Code:</b> PRC-0057	<b>CONTRACTOR DOC. NO.:</b> NFXP3-ECC-EL-MAR-00005	<b>REV</b> 2	<b>CONTRACTOR PROJECT No.</b> 10370	<b>PROJECT CONTRACT No.</b> LTC/C/NFE/3998/18
<b>SUBCONTRACTOR NAME &amp; LOGO</b> CHINA ELEVENTH CHEMICAL CONSTRUCTION W.L.L (ELECO)				<b>SUBCONTRACTOR NO.:</b> 1037025010
<b>DOCUMENT TITLE:</b> MATERIAL APPROVAL REQUEST FOR ELECTRICAL MATERIALS FOR CAMP ACCOMMODATION PORTACABIN BUILDINGS IN EPC 3				
<b>SUBCONTRACTOR DOCUMENT NO.:</b> NFXP3-ECC-EL-MAR-00005			<b>SUBCONTRACTOR REV:</b> 2	
<b>COMPANY DOCUMENT NO.:</b> NFXP3-ECC-EL-MAR-00005		<b>COMPANY REV</b> 2	<b>DOC. CLASS</b> 1	
<b>REVIEW RESPONSE BY CONTRACTOR:</b> CONTRACTOR REVIEW COMMENTS DO NOT INDICATE EITHER RESPONSIBILITY OR LIABILITY FOR ACCURACY AND COMPLETENESS OF THIS DOCUMENT OR ALTER ANY CONTRACTUAL TERMS AND CONDITIONS.				
<input type="checkbox"/> A - REJECTED <input type="checkbox"/> C - REVIEWED WITH MINOR COMMENTS <input checked="" type="checkbox"/> F - REVIEWED WITHOUT COMMENTS  <input type="checkbox"/> B - REVIEWED WITH MAJOR COMMENTS <input type="checkbox"/> R - AS BUILT <input type="checkbox"/> I - FOR INFORMATION				
DATE: <b>12.FEB.2024</b>				

COMPANY: QATARGAS OPERATING COMPANY LIMITED	Contract No.: LTC/C/NFE/3998/18
PROJECT: RLTO EXPANSION AND OFFPLOT FACILITIES OF THE NORTH FIELD EXPANSION PROJECT (EPC-3)	Doc. No.: <b>NFXP3-ECC-EL-MAR-00005</b>
CONTRACTOR: TECNICAS REUNIDAS S.A. SUBCONTRACTOR: CHINA ELEVENTH CHEMICAL CONSTRUCTION WLL	Rev.2 Page 1 of 256
DOC TITLE: MATERIAL APPROVAL REQUEST FOR ELECTRICAL MATERIALS FOR CAMP ACCOMMODATION PORTACABIN BUILDINGS IN EPC-3	

<b>CONTRACT TITLE:</b>							
<b>AGREEMENT FOR RLTO EXPANSION AND OFF PLOT FACILITIES OF THE NORTH FIELD EXPANSION PROJECT ENGINEERING, PROCUREMENT, CONSTRUCTION AND COMMISSIONING</b>							
<b>DOCUMENT TITLE:</b>							
<b>MATERIAL APPROVAL REQUEST FOR <del>E</del>ELECTRICAL MATERIALS FOR CAMP ACCOMMODATION PORTACABIN BUILDINGS IN EPC 3</b>							
							
2	04-Feb-2024	Approved For Construction	Dinesh	Gopal Ch Das	Yang Yong		
1	11-Jan-2024	Approved For Construction	Dinesh	Gopal Ch Das	Yang Yong		
0	18-Jul-2023	Approved For Construction	RAJARAJAN	GopalCh Das	Yang Yong		
B	08-Jun-2023	Issued For Approval	RAJARAJAN	GopalCh Das	Yang Yong		
A	29-May-2023	Issued for Inter-Discipline Check	RAJARAJAN	Gopal Ch Das	Yang Yong		
Rev.	Issue Date	Revision Description	Prep'd by SUBCONT.	Chk'd by SUBCONT.	App'd by SUBCONT.	Chk'd by COMPANY.	App'd by COMPANY.
COMPANY							
		<b>QATARGAS OPERATING COMPANY LIMITED</b>					
CONTRACTOR							
		<b>TECNICAS REUNIDAS S.A.</b>					
SUBCONTRACTOR							
		<b>CHINA ELEVENTH CHEMICAL CONSTRUCTION W.L. L</b>					
DOCUMENT NO.		NFXP3-ECC-EL-MAR-00005			DOC. CLASS		1

	<h2 style="margin:0;">MATERIAL APPROVAL REQUEST</h2>	No.: 10370-CON-GEN-30 Rev.: 1 Date: 10-MAY-2023 Page: 1 of 1
---	--	---

PROJECT: NFE EXPANSION PROJECT EPC-3	CONTRACTOR/SUBCONTRACTOR: CHINA ELEVENTH CONSTRUCTION COMPANY	QR CODE
AREA / UNIT / SYSTEM / SUBSYSTEM: Rito Expansion and off plot facilities of the north field Expansion project (EPC-3)	ITP/ACTIVITY No.:N/A	
ELEMENT / TAG No.: N/A	INSPECTION TYPE CONTRACTOR/COMPANY:	
TEST PACKAGE:N/A	REPORT No. / RFI: NFXP3 - ECC-EL-MAR-00005	

This certificate does not exempt the Subcontractor from the Terms of the Contract, Project Specifications or Quality Procedures but confirms that all these Tests have been performed according to them.

DISCIPLINE					
	CIVIL		BUILDING FINISHING		PIPING
	STRUCTURAL		MECHANICAL	X	ELECTRICAL
					INSTRUMENTATION
					OTHERS: _____

**We request approval to the following material:**

MATERIAL DESCRIPTION	MATERIAL SPECIFICATION	MATERIAL TO BE USED FOR	SUPPLIER / MANUFACTURER / VENDOR	SUPPLIER / MANUFACTURER / VENDOR LOCATION
LIGHTING FIXTURE - LED SURFACE MOUNTED	301-91-EL-SPC-00014	PORTACABIN BUILDING	ANHUI SHINGEL LIGHTING TECHNOLOGY Co. Ltd.	CHINA
SWITCHES & SOCKETS	301-91-EL-SPC-00014	PORTACABIN BUILDING	TENBY	UAE
DB & BREAKERS	301-91-EL-SPC-00014	PORTACABIN BUILDING	HAGER	CHINA
WIRE	301-91-EL-SPC-00014	PORTACABIN BUILDING	SEASHORE CABLES FACTORY	QATAR
WIRE		PORTACABIN BUILDING	QICC - NEXANS	
WIRE	301-91-EL-SPC-00014	PORTACABIN BUILDING	NUHAS OMAN L.L.C.	OMAN
WIRE	301-91-EL-SPC-00014	PORTACABIN BUILDING	DOHA CABLES	QATAR
EMERGENCY LIGHT	301-91-EL-SPC-00014	PORTACABIN BUILDING	ANHUI SHINGEL LIGHTING TECHNOLOGY Co. Ltd.	CHINA
EMERGENCY LIGHT CONVERTER & BATTERY	301-91-EL-SPC-00014	PORTACABIN BUILDING	EFFORT	CHINA

This material complies with Project Specification:  YES : Reference 301-00-ST-SPC-00014  NO : Comments \_\_\_\_\_

Manufacturer/Supplier included in PVL:  YES : Reference DE892162 -BF13-4793  NO : Comments\_Previous Approvals attached

REFERENCE DRAWING: Refer to attached drawings


DOCUMENTS ATTACHED: ISO Certificates / Legal Documents, Material test certificate, Data Sheet, Company Profile and supplier catalogs.

**NOTE:** The documents have been reviewed to general conformance with the contract. Such review does not relieve the subcontractor of his responsibilities under the item of the contract nor authorize to waive any contractual requirements.

- ACCEPTED
- ACCEPTED WITH COMMENTS
- REJECTED
- REVISE AND RESUBMIT

REMARKS:

Applicable Drawings:

WITNESSED/ REVIEWED BY:	SUBCONTRACTOR QUALITY	CONTRACTOR CONSTRUCTION	CONFIRMED		COMPANY
			Requested by Quality	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	
SIGNATURE:					<div style="font-size: 2em; color: blue; text-align: center;">/</div>
PRINT NAME:	RAJARAJAN	Jordan Evangelista	Bipin Palrose	Christopher James Bond	
DATE:	04-Feb-24	12-FEB-2024	07-Feb-2024	18-Feb-2024	

Code A- Approved/Reviewed with no comments

<b>MAIN CONTRACTOR</b> THAMCO 		<b>Material Approval Submittal</b> <b>PROPOSED 10 VILLAS COMPOUND</b>			<b>SUB CONTRACTOR</b> 		
<b>EMPLOYER</b> MR. JABER A. KHAMIS AL-SULAITI				<b>CONSULTANT</b>  <b>Eng. Adnan Saffarini</b>			
<b>Submittal Ref No:</b>		<b>MAS/E/04</b>		<b>Rev.</b>	<b>1</b>	<b>Date:</b>	<b>20-07-2020</b>
To Resident Engineer. <b>Eng. Orwa</b>							
<b>Originator</b>		10 Villas (G+F+PH) & Services		<b>Subcontractor / Supplier:</b>		AL-Tahrir Trading Co.	
<b>Material / Product Title:</b>				<b>ELECTRICAL</b>			
<b>Description - Specified</b>				<b>Specification Section</b>			
Electrical Wires M Cables Al-Mansoor Factory for Cables				<b>Paragraph No:</b>			
				<b>Supplier / Manufacturer</b>			
				<b>Name:</b> AL-Mansoor Factory for Cables			
				<b>Address:</b> New Industrial Area			
				<b>Tel:</b> 44888499			
				<b>Fax:</b> 44888499			
<b>Material / Product Description - Proposed</b>				<b>Attachments</b>		<b>Copy No</b>	
				1- Product Data		Attached	1
				2- Samples		Attached	1
Electrical Wires M Cables Al-Mansoor Factory for Cables				3- Drawings		N/A	0
				4- Others		N/A	0
I hereby certify this submittal data has been reviewed and approved prior to submission to the Project Management Consultant and Engineer and the information contained within this submittal has been checked and coordinated with the requirements of the work and the contract.							
<b>Project Manager.</b> Name: Eng. Nadim / Thamco Signature:  Date: 21-07-2020				<b>Subcontractor Project Manager</b> Name: Eng. Khaled / Al-Tahrir Company Signature:  Date: 21-07-2020			
<b>For use by Project Management Consultant</b> <b>Approval Status</b> A - Approved <input type="checkbox"/> B = Approved As Noted <input checked="" type="checkbox"/> C - Rejected <input type="checkbox"/> D - Resubmit <input type="checkbox"/>						<b>Acknowledgement of Receipt</b> Date: _____ Signature: _____ Stamp: _____	
<b>Comments</b> * Final approved as subject to kahramaa approved.						 BY: _____	
 Name: _____ Signature: _____ Date: _____							
For Use by ACC DC		ACC		Date Returned: 		Stamp	

**MATERIAL SUBMISSION**

PROJECT TITLE: THE CONSTRUCTION, COMPLETION AND MAINTENANCE OF VIADINAT AL MAWATER PHASE 3	LOCATION : <b>Um Garn</b>
3A NO.: MA-	SUBMITTAL NO. : <b>HCC/MAM/MS/EL/05A</b>
DATE : <b>26 September 2020</b>	Rev: <b>00</b>
CONSULTANT: <b>CEG International</b>	CONTRACTOR : <b>HassanESCO Trading &amp; Contracting</b>

DISCIPLINE :  C & S     ARCH     MEP     ELECT     HVAC     FF     DR     PL  
 LANDSCAPE     INTERIOR DESIGN    MISC./ OTHER

Submitted For:  Review & Approval     Re-Submitted for Review & Approval

SPECIFICATION REF: Elect. Spec. - 21.2.15	MATERIAL ORIGINALLY SPECIFIED:
BOQ ITEMS: ALL ITEMS	DESCRIPTION :
DRAWING REF: ALL BUILDINGS	<b>SINGLE CORE WIRES AND FLEXIBLE CABLES</b>

LOCAL AGENT:	MANUFACTURES:
Name : <b>AL MANSOOR FACTORY</b>	Name : <b>AL MANSOOR FACTORY</b>
Address : <b>QATAR</b>	Address : <b>QATAR</b>
PO Box :	PO Box :
Tele/Fax :	Tele./Fax :
Web Site :	Web Site :

DATE REQUIRED@ SITE:	COUNTRY OF ORIGIN: <b>QATAR</b>
DELIVERY PERIOD:	TOTAL QUANTITY:

SUPPORTING INFORMATION:  LITERATURE     SAMPLES     CERTIFICATES

**CONTRACTOR'S SIGNATURE & SEAL:**

We certify that the above submitted item has been reviewed in details and is correct and in strict conformance with the contract requirements except as otherwise stated above:

Name: <b>Eng. Ahmed Fahmy – MEP Project Manager</b>	Sign:  Date: <b>26/9/20</b>
Name: <b>Eng. Ahmed Hamza – QA/QC Manager</b>	Sign:  Date: <b>27-09-2020</b>
Name: <b>Eng. Hani Said – Project Manager</b>	Sign:  Date: <b>27.9.2020</b>

**CONSULTANT COMMENTS:**

*Refer to the attached comments sheet.*

Name: \_\_\_\_\_ Sign : \_\_\_\_\_

APPROVED <input type="checkbox"/>	APPROVED WITH COMMENTS <input checked="" type="checkbox"/>	REVISE & RESUBMIT <input type="checkbox"/>	REJECTED <input type="checkbox"/>
ADD'L INFO. REQ'D <input type="checkbox"/>	SAMPLE / TEST REQUIRED <input type="checkbox"/>	FOR INFO. <input type="checkbox"/>	OTHERS <input type="checkbox"/>

Approval by the Consultant and or the Engineer shall not relieve the Contractor of his obligation under the Contract, and the Contractor shall be solely responsible for the soundness and correctness of the submitted materials and documents.

Reviewed By: 	PROJECT MANAGER SIGNATURE: 	ACKNOWLEDGED BY CONTRACTOR SIGN: 	DATE: <b>27-09-2020</b>
--	---	--	-------------------------



Date : 28-Nov-20 NEW SUBMITTAL  RESUBMITTAL   
 Project Name : Food Storage Area (G), Accommodation (G+2), Admin & Showroom (G+1) Submittal No.: P2-MS-HRP-ELE-0006 Rev.: 2  
 Project No. : 23  
 Customer : High Record Project

**DESCRIPTION**  
 Material Submittal for Wires  
 (Brand : M Cables - C.O.O.: Qatar)

Drawing Ref. \_\_\_\_\_  
 Specs. Ref. \_\_\_\_\_  
 BOQ Ref. \_\_\_\_\_  
 B.S. Ref. \_\_\_\_\_

Attachment  Literature  Test Certificates  Samples

**MANUFACTURER NAME:** Al Mansoor Factory for Cables **SUPPLIER NAME:** Al Mansoor Factory for Cables  
 Address: El Markhia Roundabout, Doha - Qatar  
 Local Agent: Al Mansoor Factory for Cables  
 Post Box: 41116 Telephone No. (+974) 44888499 Fax No. (+974)

**DELIVERY**

Production Period   
 Delivery Ex. Works   
 Total Delivery Time

The Contractor certifies that the submitted items have been reviewed in detail and are correct and in strict conformance with the Contract documents except as otherwise stated.

**CONSULTANT COMMENTS**

(1) Approved  (4) Revise & Re-submit  (7) Mnfctr./ Supplier   
 (2) Approved as Noted  (5) Addt'l. Info Required  (8) Guarantee Required   
 (3) Rejected  (6) Sample/ Test Required  (9) Others

**REMARKS**

- No objection to using the "M cables" brand for wires only in the building in condition achieve the vendor list and contract items if any.

Signature *[Signature]* Date 29-11-2020

**CUSTOMER/ENGINEERING DEPARTMENT COMMENTS**

Signature \_\_\_\_\_ Date \_\_\_\_\_

المعماريون المقدمون للتصميم

Approved

Approved as noted

Revise/Resubmit

Sample Required

Tests Required

Additional Information Required

Manufacturer's Guarantee Required

Date: 29-11-2020  
 Signature: *[Signature]*

Approval by the Consultant and or the Customer shall not relieve the Contractor of his obligation under the Contract, and the Contractor shall be solely responsible for the soundness and correctness of the submitted materials and documents.

For Contractor Use

For Consultant Use

For Customer Use

RECEIVED  
 28 NOV 2020  
*[Signature]* 2:06



اتحاد قطر للتخطيط

QATAR DESIGN CONSORTIUM

ARCHITECTS, ENGINEERS, PROJECT MANAGERS & CONSULTANTS



Ref. No: P112-MTC-SP-MS-EL-010 – R1

Date: 14-03-2021

PROJECT:	Splash at City Center
CLIENT:	M/s Landmark Retail
CONSULTANT:	M/s Qatar Design Consortium
CONTRACTOR:	M/s Mechon Trading & Contracting WLL
MEP CONTRACTOR:	M/s Green Square Trading & Contracting WLL

TRADE  CIVIL  ARCHITECTURAL  MECHANICAL  ELECTRICAL  EXTERNAL  
 STATUS  NEW SUBMITTAL  REVISED SUBMITTAL

MATERIAL SUBMITTED: Heat Resistance Flexible Cable

Specification Ref.	BOQ Ref:	Standard Applicable	Drawing Ref:	Manufacturer
				Al Mansoor Cable
Material Submittal Iss Specified	Country of Origin	Material Required at Site on:	Expected Delivery Date & Mode of Transport	Local Supplier
	Qatar	Immediate	Immediate	Al Mansoor Factory for Cable
Valid Authority Approvals	Remarks if alternative	Comparative/ Compliance Statement	Catalogues	Guarantee/ Warranty period

**Supplier's** Contact person Name and Contact No.: Mr. Syed - 50338611  
 Contractor and Subcontractors signature and stamp



ENCLOSURES: .....

**Consultant Comments**

Compliance is acceptable to proceed with procurement and execution.

**Client Comments:**

.....

Approved  Approved as Note  Revise & Resubmit  Additional Information Required  
 Not Approved  Others.....

**Signature Date:** 18.03.2021

Architect/ Engineer..... Project Manager..... Client Rep.....

Note: Allow for at least seven working days for review.

Consultant Received      Client Received      Consultant Received      Contractor Received



**Material Transmittal**

Project Name: Floresta Gardens 107 & 109		Project No: FG107 & 109	
Owne AL MANA CAPITAL REAL ESTATE		Submittal No.: FG107-108-MT-EL-017-Rev-00	
		Date: 2/1/2022	
Submitted by: Al Seal Contracting & Trading Co. / AAC		New Submittal: <input checked="" type="checkbox"/>	
Contractor's Representative Printed Name: <u>Azzam Khedr</u>		Resubmittal: <input type="checkbox"/> Rev. <input type="checkbox"/> 0	
Signature: <u>[Signature]</u>			

Description: **SINGLE CORE WIRES AND MULTI CORE FLEXIBLE CABLES**

Drawing Ref.: **ELECTRICAL DRAWINGS**

Specification Ref.: **SECTION: 1620**

Bill of Quantities Ref.: \_\_\_\_\_

Other Ref.: \_\_\_\_\_

Attachment:

Literature/Catalogue     Test Certificates     Samples

Discipline Involved:  Architectural     Structural     Mechanical     Electrical     Interior Design     Others:

Manufacturer/Supplier

From Approved Vendor List     Equivalent or Approved

Name of Manufacturer/Supplier: **AL MANSOOR CABLES**

Address: \_\_\_\_\_ Local Agent: **AL MANSOOR FACTORY FOR CABLES**

Agent Tel. No.: \_\_\_\_\_ Fax No.: \_\_\_\_\_

Delivery: <input type="checkbox"/>	Country of Origin: <b>QATAR</b>
Availability: <input type="checkbox"/>	Mode of Transportation: _____
Locally Manufactured: <input type="checkbox"/>	Overland: <input type="checkbox"/>
Overseas: <input type="checkbox"/>	Air Freight: <input type="checkbox"/>
	Sea Freight: <input type="checkbox"/>
Manufacturer: _____	Programme: _____
Production Period: <input type="checkbox"/>	Latest Date of Orders: <input type="checkbox"/>
Delivery Ex Works: <input type="checkbox"/>	Date Material Required: <input type="checkbox"/>
Total Delivery Time: <input type="checkbox"/>	Expected Date on Site: <input type="checkbox"/>

Approved:     Revise & Resubmit:     Additional Info. Required:

Approved as noted:     Rejected:     Others:

Comment:

1) Refer to The attached comment sheet and comply accordingly.

2) Alternative material not allowed to use on site unless Contractor obtaining Consultant approval.

Consultant: Azzam Khedr    [Signature]    06/01/2022 B

Sr. Elec. Eng    \_\_\_\_\_

Printed Name    Signature

Owner - Engineering Department Comments (if applicable): \_\_\_\_\_

Signed by: Mr. George Papadopoulos    [Signature]    06/01/2022

Printed Name    Signature    Date

Received by Contractor: \_\_\_\_\_

Printed Name    Signature

Stamp: **AL SEAL CONTRACTING & TRADING CO.**

Stamp: **RECEIVED**

Stamp: **AL SEAL CONT & TRAD CO.**

Stamp: **12 JAN 2022**

Stamp: **HEAD OFFICE**     **SITE OFFICE**

Stamp: **63 JAN 2022**

Stamp: **Received by: [Signature]**

Date : 6<sup>th</sup> Jan 2022  
Project : Floresta Garden 107 & 108  
Subject : **SINGLE COREWIRES & DATA NETWORK PASSIVE CABLING**  
Ref : FG107-108 MT-EL-017-Rev-00

**CONSULTANT'S COMMENTS**

Reference to Material Transmittal Ref. # FG107-108-MT -EL-017-Rev-00 dated 03<sup>rd</sup> December 2021

Please refer to our review/ comments as follows:

- 1- Installation, Testing and commissioning shall be in full compliance with Kahramaa Regulation, latest QCS edition, project specifications & to the full satisfaction of the Engineer.
- 2- This approval is not valid for the rest of the projects that are under the supervision of DSG.
- 3- Quantity & type are subject to contractor's approved shop drawing.
- 4- Details of installations to be submitted prior to work commencement.
- 5- The warranty Certificate for products shall be as per standard and starting from the date of final acceptance of Testing & Commissioning.
- 6- Provide list of materials including area of application, type and size of cables with contractor's and Supplier's signature & stamp.
- 7- Provide installation method statement with signature and stamp.
- 8- Final approval is subject to passing of the Testing and commissioning.
- 9- All proposed materials should be as per the latest IFC Drawings
- 10- Final approval is subject to mock-up passing result.
- 11- System specialist and Contractor shall fully comply with the latest UDC guidelines and specifications.

Regards,

**Action Code: APPROVED AS NOTED**

Azzam Khedr  
Sr. Electrical Engineer

Mr. George Papadopoulos  
Project Manager

  
06-1-2022<sup>2</sup> B

for:   
06/01/2022



Project Name : Design & Construction of The Ned Doha -  
Renovation of Former Ministry of Interior Building

Project No. :U0845DCDC

Oryx Corniche Development QPJSC

David Chipperfield Architects


Turner & Townsend



**MATERIAL APPROVAL REQUEST**

MAR NO.	: UCC845-EMEP-MAR-E-0033	Rev.00	Date: 16-01-22	Discipline: ELECTRICAL	Activity	SINGLE CORE WIRES (PVC)
---------	--------------------------	--------	----------------	------------------------	----------	-------------------------

CLIENT : Oryx Corniche Developments QPJSC / Soho House & Co  
 INTERIOR DESIGN : Soho House & CO  
 PROJECT MANAGEMENT : Turner & Townsend  
 DESIGN ARCHITECT : David Chipperfield Architects  
 SUPERVISION CONSULTANT : EHAF Qatar  
 STR/MEP ENG CONSULTANT : Cundall  
 DESIGN CONSULTANT : Dar Al-Handasah  
 MAIN CONTRACTOR : Urbacon Trading & Contracting  
 SUB CONTRACTOR : Elegancia MEP



Material Detail		List of Enclosures (Tick the Related Box)
Item Description	SINGLE CORE WIRES (PVC)	
Spec./BOQ/Drwg.	QCS 2014 (Section 21 - Part 06)	
Manufacturer Specified	AL-MANSOOR FACTORY FOR CABLES (M CABLES)	
Material Proposed	SINGLE CORE WIRES (PVC)	
Local Supplier	SEA SHORE CABLES FACTORY	
Reasons for Alternatives	Option-03	
Remarks		

- Vendor's Technical
- Test Results
- Compliance Statement
- Data Specification
- Samples
- List of Previous Projects Done
- Others (Specification)

<b>Urbacon Contracting and Trading LLC</b>		<b>Consultant</b>
Sub-Con Rep's: Mr. Hassan Al Jabri	MEP Manager:	Received by:
Procurement Manager:	Tech. Manager:	Date:
QA/QC Manager:	Date: 16/1/2022	
Sr. Project Manager:		

Response required by : **FOR THE USE OF CONSULTANT**

Action:  A - Approved  B - Approved With Comments  C - Revise and Resubmit  D - Rejected

Comments :  
 Refer to Comments on attached A4 sheet.

Project Director: Date: 17/1/2022

Received By : Urbacon Contracting and Trading LLC  
 Project Director: \_\_\_\_\_ Date: \_\_\_\_\_







**PROJECT: PALACE HOTEL & SPA**  
**PROJ. NO: UCC864**






**ASSETS**  **أسيٲس**  
 real estate development

**MATERIAL APPROVAL REQUEST**

MAR NO. :	UCC864-MAS-E-0018	Rev. 01	Date: 05 FEB 2022	Discipline: EL	Activity
CLIENT :	ASSETS REAL ESTATE DEVELOPMENT CO. W.L.L.				
CONSULTANT :	GHD				
MAIN CONTRACTOR :	URBACON TRADING & CONTRACTING W.L.L.				
SUB CONTRACTOR :	ELEGANCIA ELECTRO MECHANICAL				No of Copies Attached:

Material Detail		List of Enclosures (Tick the Related Box)
Item Description	MATERIAL SUBMITTAL FOR SINGLE CORE WIRES	<input type="checkbox"/> Vendor's Technical
Spec./BOQ/Drwg.	QCS 14, SECTION 21, PART 21, CLAUSE : 6	<input checked="" type="checkbox"/> Test Results
Manufacturer Specified	SINGLE CORE WIRES	<input checked="" type="checkbox"/> Compliance Statement
Material Proposed	SINGLE CORE WIRES	<input checked="" type="checkbox"/> Data Specification
Manufacturer / Local	SEAHORE / AL MANSOOR FACTORY FOR CABLES	<input type="checkbox"/> Samples
Reasons for Alternatives	AVAILABILITY & DURATION OF DELIVERY	<input checked="" type="checkbox"/> List of Previous Projects Done
Remarks	N/A	<input type="checkbox"/> Others (Specification)

<b>Urbacon Contracting and Trading LLC</b>		<b>Consultant</b>	
Originator: 	MEP Manager: 	Received by: 	
QA/QC Manager: 	Tech. Manager: 	Date: 	
Project Director: 	Date: 	Review Form No. _____	

**Response required by :** **FOR THE USE OF CONSULTANT**

Action:  A - Approved     B - Approved With Comments     C - Revise and Resubmit     D - Rejected

Comments :

No Objection

Project Director:  **RAVI MANI**    Date: **07 FEB 2022**

GHD GLOBAL PVT LTD  
 Clients People Performance  
 GHD Number 0965  
 P.O.Box 14222 Doha, Qatar  
 Telephone: (974) 4429 2222 - Fax: (974) 4429 2223

PALACE HOTEL & SPA  
 GHD Project number 1255190

Correction or comments made on this document during this assessment do not relieve the contractor from compliance with the requirements of the drawings and specifications.

This assessment is for the review of general conformance with the design concept of the work and general compliance with the information given in the contract documents.

Rejection is given to deviations from contract documents not clearly identified irrespective of this assessment's outcome below.

The contractor is responsible for confirming and correcting all quantities and dimensions, selecting the right processes and equipment, of construction, and performing their work in safe manner.

Code A: Approved  
 Code B: Approved with Comments  
 Code C: Revise & Resubmit  
 Code D: Rejected

By: **M.Nazih**    Date: **7/2/2022**

Received By : **Urbacon Contracting and Trading LLC**

Project Director: \_\_\_\_\_ Date: \_\_\_\_\_

**Urbacon Contracting and Trading**  
 Tel +974 4429 2211 – 4429 2222 | Fax +974 4429 2123 | Email info@urbacon-intl.com  
 PO Box 201184, Doha, Qatar



Al Jaber Trading & Contracting Co. W.L.L.

### MATERIAL SUBMITTAL

Project Name: THE QATAR SCHOOLS PPP DEVELOPMENT PROGRAM – PACKAGE 1

Submittal No.:	Revision	Date
JTC-PPPS-P1-MAT-ELE-0068	00	07 Feb. 22

Project No. : BA/2019/C/001/G

Client : Authority - ASHGHAL

Project Company: DAE / Management Consultant: QPM

Supervising Consultant: AEB – ARAB ENGINEERING BUREAU


Contractor : JTC – AL JABER TRADING AND CONTRACTING CO.

- Discipline:  Arch.  Civil  Mech.  Elect.  
 Struc.  Hard Landscape  Plumbing  
 Soft Landscape  Irrigation  
 Interior Design  Information Tag  
 Others \_\_\_\_\_

#### SUBMITTAL CONTENT

<input checked="" type="checkbox"/>	Catalogue/Brochure	<input checked="" type="checkbox"/>	Technical Data Sheet	<input checked="" type="checkbox"/>	Compliance Statement
<input checked="" type="checkbox"/>	Country of Origin Certificate	<input checked="" type="checkbox"/>	Material Sample	<input type="checkbox"/>	Mock up
<input checked="" type="checkbox"/>	Vendor Guarantee/Warrantee	<input checked="" type="checkbox"/>	Drawing Reference	<input checked="" type="checkbox"/>	Others


S/N	DESCRIPTION	Manufacturer	Supplier	BOQ Item No.	Specs. Ref.
1	WIRE – including with sample  Remarks: Alternative Material Submittal For JTC-PPPS-P1-MAT-ELE-0017 (M/s Doha Cables)	Al Mansoor Factory (M- Cables) – Qatar	Al Mansoor Factory for Cables		QCS 2014 Sec. 21 Part 6 Project Specification 21.2.13



#### Additional Information (if applicable)

Material Date Required:	Material Production period:	Total Delivery Time:	Expected Arrival on site:

Contractor		Supervision Consultant	
Engr. Anifur Shahulhameed MEP Coordinator	Engr. Noel L. Escobido Project QA/QC Manager	Engr. Mohammed Salem Project Manager	Date



Action Code: <input type="checkbox"/> A= Approved <input checked="" type="checkbox"/> B= Approved as Noted <input type="checkbox"/> C= Revise & Resubmit <input type="checkbox"/> D= Rejected	Comments:
Discipline Engineer: <u>A.M</u>	Date: <u>20-02-22</u>

Project Management:		Contractor	
Technical Manager: _____	Project Manager: _____	Received by: _____	Date: _____
Date: <u>21/2/22</u>	Date: _____		

**APPROVED AS NOTED**



LOCATION: MINISTRY OF MUNICIPALITY AND ENVIRONMENT PHASE-02 EXTENSION @ WEST BAY

MATERIAL APPROVAL REQUEST (MAR)

<b>Project Name</b>	<b>From : SALAM INDUSTRIES</b>	<b>MAR No. 1340-MME-MAR-EL-0011 Rev 01</b>
<b>Fitout at MINISTRY OF MUNICIPALITY AND ENVIRONMENT P2 EXTENSION @ WEST BAY</b>	<b>To : AL-KASHAF INTERNATIONAL</b>	<b>Date Submitted : 15-03-2022</b>

Submittal Contents

Material / Sample
  Catalogue / Brochure
  Others

Trade / Discipline

Structural & Architectural
  Fire Fighting
  Electrical  
 HVAC
  Plumbing
  Fire Alarm

Submission Description

Material Submittal for PVC WIRES with reply to consultant comments

Manufacture / Supplier Details

Local Supplier / Agent	Manufacture	Country of Origin
SEASHORE TRADING	AL MANSOOR CABLES	QATAR

CONTRACTOR'S REVIEW

Prepared by :  Eng. Anandhu R. Name / Sign / Date	Recommended for Approval by : (Contractor's PM)  Eng. Subash Name / Sign / Date	Stamp 
--	--	-----------

NOTE: We certify that the document submitted herewith have been reviewed in details and are in strict conformance with the contract documents, drawings and specifications except as other wise stated.

COMMENTS BY THE CONSULTANT

- No objection subject to Supplier Compliance.  
 - Compliance statement to be stamped by Supplier.  
 - Approval limited to 35mm<sup>2</sup> wires / Cables  
 - approval is sub related to the above mentioned project only.


SUBMITTAL REVIEW STATUS

APPROVED  
 APPROVED AS NOTED  
 REVISE AND RESUBMIT  
 REJECTED

SUPERVISION CONSULTANT'S SIGNATURE

For & On behalf of AL-KASHAF INTERNATIONAL

Eng.   
 Name / Sign  
 Date



AL MIRQAB REAL ESTATE  
DEVELOPMENT & INVESTMENT  
COMPANY



**Material Transmittal**

Project Name:	Floresta Gardens FG-102-110, The Pearl Qatar	Date:	28/03/2022
Client:	AL MIRQAB REAL ESTATE DEVELOPMENT & INVESTMENT COMPANY	Submittal No.:	AS-FG102-110-MT-EL-041-Rev-00
Submitted by:	AI Seal Contracting & Trading Co. W.L.L / AAC	Firas Dibajeh - Project Manager	
	Company Name	Representative: Signature over Printed name	Mobile no.

- New Submittal   
  - Re-submittal   
  - Revision   
  - Others

Description: **SINGLE CORE WIRE - ALTERNATIVE OPTION**

Drawing Ref: \_\_\_\_\_

Specification Ref: **QCS-2014, SECTION: 21, PART-6**

Bill of Quantities Ref: \_\_\_\_\_

Other Ref: \_\_\_\_\_

Attachment:  Literature/Catalogue     Test Certificates     Samples

Discipline Involved:  Architectural     Structural     Mechanical     Electrical     Interior Design     Others: Act. Info.

**Manufacturer/Supplier**

From Approved Vendor List     Equivalent or Approved

Name of Manufacturer/Supplier: **M CABLES/ AL MANSOOR CABLES**

Address: **ARCHITECTURAL STRUCTURAL MECHANICAL ELECTRICAL SUPERVISION INTERIOR DESIGN**

Local Agent: **AL MANSOOR FACTORY FOR CABLES / SEASHORE CABLES FACTORY**

Agent Tel. No.: \_\_\_\_\_ Fax No.: \_\_\_\_\_

Country of Origin: **QATAR**

Mode of Transportation:  Overland     Air Freight     Sea Freight

Programme:  Latest Date of Orders: \_\_\_\_\_

Date Material Required: \_\_\_\_\_

Expected Date on Site: \_\_\_\_\_

Locally Manufactured: **28 MAR 2022**

Overseas: \_\_\_\_\_

Manufacturer: **Received by: [Signature]**

Production Period: **HEAD OFFICE / SITE OFFICE**

Delivery Ex Works: \_\_\_\_\_

Total Delivery Time: \_\_\_\_\_

Approved:     Revise & Resubmit:     Additional Info. Required:   
 Approved as noted:     Rejected:     Others:

Comments:


- Installation shall be done as per QCS & kWhM regulations

- Wire brands & colors shall not be mixed (shall be uniform) within terminations

Consultant: A. Chammas    [Signature]    31/03/2022

Printed Name    Signature    Date

Owner - Engineering Department Comments (if applicable):



Signed by: A. Chammas    \_\_\_\_\_    \_\_\_\_\_

Printed Name    Signature    Date

Received by: \_\_\_\_\_

Contractor: \_\_\_\_\_

Date : 20-Apr-22      NEW SUBMITTAL       RESUBMITTAL

Project Name : PROPOSED PALACE (B+G+1+ROOF) + MAJILES + OUTDOOR BLOCK 01 + BLOCK 02

Project No. :      Reference No.: AGTC-EPEMS-MAT-EL-10- REV.3

Customer : M/S SHIEKH ESSA HAMAD J T AL-THANI

**DESCRIPTION**      Drawing Ref.      Specs. Ref.      QCS 2014 SEC. 21 PART 6.2.2

**WIRES**      BOQ Ref.      B.S. Ref.

(M CABLES - QATAR)

Attachment      Technical Submittal       Literature       Test Certificates       Samples

**MANUFACTURER/SUPPLIER**

Name      Seashore Cables ( AL Mansoor Factory for Cables)

Address      P.O.Box. 41116, Doha, Qatar

Local Agent      Seashore Cables ( AL Mansoor Factory for Cables)

Post Box      41116, Doha Qatar      Telephone No.      (+974) 4488 8499      Fax No.      (+974) 3324 2127



**DELIVERY**

<b>AVAILABILITY</b>		<b>MODE OF TRANSPORT</b>	
Locally Manufactured	<input checked="" type="checkbox"/>	Overland	<input checked="" type="checkbox"/>
CCASG Manufactured	<input type="checkbox"/>	Air Freight	<input type="checkbox"/>
Overseas	<input type="checkbox"/>	Sea Freight	<input type="checkbox"/>
<b>MANUFACTURE</b>		<b>PROGRAMME</b>	
Production Period	<input type="checkbox"/>	Latest Date for Order	<input type="checkbox"/>
Delivery Ex. Works	<input type="checkbox"/>	Date Material Required on Site	<input type="checkbox"/>
Total Delivery Time	<input type="checkbox"/> 4 - 6 Weeks		

The Contractor certifies that the submitted items have been reviewed in detail and are correct and in strict conformance with the Contract documents except as otherwise stated.

**CONSULTANT COMMENTS**

(1) Approved <input checked="" type="checkbox"/>	(4) Revise & Re-submit <input type="checkbox"/>	(7) Mnfr. / Supplier <input type="checkbox"/>
(2) Approved as Noted <input type="checkbox"/>	(5) Addtl. Info Required <input type="checkbox"/>	(8) Guarantee Required <input type="checkbox"/>
(3) Rejected <input type="checkbox"/>	(6) Sample/ Test Required <input type="checkbox"/>	(9) Others <input type="checkbox"/>

**REMARKS**      *As per attached Km Regulation*

Signature      Date

**CUSTOMER/ENGINEERING DEPARTMENT COMMENTS**

Signature      Date

Approval by the Consultant and or the Customer shall not relieve the Contractor of his obligation under the Contract, and the Contractor shall be solely responsible for the soundness and correctness of the submitted materials and documents.

RECEIVED  
21 APR 2022  
9:20

For Contractor Use

For Consultant Use

For Customer Use

### SUBMITTAL FOR APPROVAL OF MATERIALS

Project Name:	Design and Build of Grandstand in Al-Uqda Equestrian Complex	Submittal No:	38
Contract Ref.:		Re. No.:	R00000.01-ELEC-SAM-038 – Rev.01
Client:	Public Works Authority	Date:	26 - April – 2022
Supervision Consultant:	EGEQ Qatar for Engineering Consultation W.L.L.	Copies:	1 Hard Copy + CD soft copy
Designer:	GCG	From:	Brickstone (BSTC)
Contractor:	BrickStone Trading and Contracting	To:	EGEQ

To: SUPERVISION CONSULTANT

We request your approval on the following Materials:

### MATERIAL DESCRIPTION: WIRES & FLEXIBLE CABLES (Alternative)



Area of Application		BOQ Ref. No.:	
Drawing Ref.		Standards:	
Specification		Document No.:	DBG-BTC-EGEQ-MS-ELEC-038-REV.01
Enclosures	MATERIAL SUBMITTAL DOCUMENT (SOFT + HARD COPY)		

MANUFACTURER / SUPPLIER	
Company Name	AL MANSOOR FACTORY FOR CABLES (SEASHORE CABLES FACTORY)
Address	Zone No. 81, Building No. 161, Street No. 24 – P.O. Box: 41116, New Industrial Area, Doha - Qatar
Local Agent	

DELIVERY	
Country of Origin	QATAR
Availability	
Delivery Program	
Ex-works Total Duration	
Estimated Date of Arrival on Site	

FOR THE CONTRACTOR:	
Name:	Engr. Sayed Omar
	Project Manager
Signature:	
Date:	27.4.2022




CONSULTANT'S COMMENTS:

*- Refer to comments on attached CR sheet*

- Submittal Status:
- A- Approved As Submitted\*
  - B- Approved as Noted\*
  - C- Revise /Resubmit
  - D-Disapproved-Resubmit
  - E-Receipt acknowledged

The materials are accepted. This does not relieve the Contractor of his responsibility to verify and use materials which comply with the Specifications and Contract obligations.

FOR SUPERVISION CONSULTANT	
Name:	
Signature:	
Date:	12/5/2022

Receiving by Contractor	
Name:	
Signature:	
Date:	



Comments Resolution Sheet

Project No.:	C2021/12	EGEC Project Code
Contract Title:	Design and Build of Grandstand in AL UQDA Equestrian Complex	
EGEC Transmittal / Submittal Ref. No.:	R00000.01-ELEC-SAM-038	Date
Document No.:	DBG-BTC-EGEC-MS-ELEC-038	Document Revision
Document Title:	Submittal for Approval of Material for Wire & Flexible Cables - Alternative (Al Mansoor)	
Document's Status:	Approved as Noted	
<b>No.</b>	<b>EGEC's Comments</b>	<b>Brick Stone Response</b>
1.	EGEC approval does not relieve the contractor of his obligations under his contract.	
2.	Quantity and selection of materials shall fo low approved shop drawings & site conditions.	
3.	Engineer reserve the right to reject the material if found deviated from compliance statement or if not complied with the project specifications.	


EGEC QATAR FOR ENGINEERING CONSULTATIONS W.L.L.  
PROJECT SUBMITTALS BY THE CONTRACTOR



**REQUEST FOR MATERIAL APPROVAL**

PROJECT : Construction of Satellite Monitoring System	REPORT NO. : BPD0020CT-MS-EL-018
CLINET : Public Works Authority (ASHGHAL)	DATE : 23-May-2022
CONTRACTOR : Brickstone Trading & Contracting	CONTRACT NO : C2021/80
MEP CONTRACTOR : Q-TEC Engineering W.L.L.	DOCUMENT NO : SMS-BTC-PWA-MS-ELEC/018

<b>DEPARTMENT</b>	
ARCH <input type="checkbox"/>	CIVIL <input type="checkbox"/>
ELEC <input checked="" type="checkbox"/>	TEL <input type="checkbox"/>
HVAC <input type="checkbox"/>	MECH <input type="checkbox"/>
OTHER	



DESCREPTION	ATTACHMENT
DRAW. REF.	SCOPE OF SUPPLY <input checked="" type="checkbox"/>
BOQ REF.	DATA SPECIFICATION <input checked="" type="checkbox"/>
MATERIAL DESC. FLEXIBLE CABLE	SAMPLE
MANUFACTURER SEASHORE CABLE FACTORY	TEST CERTIFICATE <input checked="" type="checkbox"/>
SUPPLIER/ AGENT SEASHORE CABLE FACTORY	VENDOR TECHNICAL <input checked="" type="checkbox"/>
QUANTITY REQUIRED	COMPLIANCE STATEME <input checked="" type="checkbox"/>
COUNTRY OF ORIGIN QATAR	PREVIOUS APPROVALS <input checked="" type="checkbox"/>

ADDRESS/ TEL/ FAX P.O. Box 41116, Doha - Qatar

<b>SUBMITTED BY</b>		
	CONTRACTOR ENG.	CONTRACTOR PROJECT MANGER
NAME	Engr. Arun Kumar	Mahmoud Abdulaziz
SINGED	<i>[Signature]</i>	<i>[Signature]</i>
DATE	23/5/2022	23/5/2022

**COMMENT BY GCG CONSULTANT ENGINEER**  
Flexible cable 3x2x.5 HOSVV-F-CU/PVC/DVC 90C 300/500 V is approved for lighting circuits. Nonetheless the electrical contractor shall ensure the voltage drop for connected load. Install the cable as per approved method statement, QLS2014, KM regulations and approved shop drawings. MIR shall be raised along with approved MAR, Shop drawing, delivery note and test certificates.

<b>STATUS</b>		
APPROVED	APPROVED WITH COMMENTS	REVIISED & RE-SUBMIT NOT APPROVED
	GCG- CONSULTANT ENGINEER	GCG-PROJECT MANAGER
NAME	Fareh Sultan	Engr. Haydar Theabb
SINGED	<i>[Signature]</i>	<i>[Signature]</i>
DATE	24-5-22	24/5/2022

Approval by the consultant shall not relieve the contractor of his obligation under the contract , the contractor shall be solely responsible for the soundness and correctness of the submitted material and documents.



**DOCUMENTS TRANSMITTAL**

To	M/s Brick Stone Trading & Cont.	Trans. No.	BPD0020CT-TRN-GCG-BSTC-22-0437
Attn.	Engr. Mahmoud Abdelaziz - PM	No of Copies	1
From	<b>GULF CONSULTING GROUP</b> Engr. Haydar Theabb - Project Manager	Date	25.05.2022
Project	Construction of Satellite Monitoring System		
Here enclosed please find the following documents:			

S/N	Document No	Description	Rev.	Status
1	BPD0020CT-MS-EL-18	Flexible Cable (Seashore Cable Factory)	0	B
		End		

Notes:

\* Status Legend: A=Approved. B=Approved as Noted C= Revise/Resubmit D=Disapproved-Resubmit I= Information

Discipline:

Architectural	<input type="checkbox"/>	Electrical	<input checked="" type="checkbox"/>	HSE	<input type="checkbox"/>	Planning	<input type="checkbox"/>	Technical	<input type="checkbox"/>
QA/ QC	<input type="checkbox"/>	Mechanical	<input type="checkbox"/>	QS	<input type="checkbox"/>	Drafting	<input type="checkbox"/>	Accounting	<input type="checkbox"/>
Admin	<input type="checkbox"/>	Marketing	<input type="checkbox"/>	Civil	<input type="checkbox"/>	Structural	<input type="checkbox"/>		

Encloses: **Pre Qualification**  Material Submittal  Document

Specification	<input type="checkbox"/>	Drawings	<input type="checkbox"/>	CD	<input type="checkbox"/>	Sketches	<input type="checkbox"/>	Method Statement	<input type="checkbox"/>
---------------	--------------------------	----------	--------------------------	----	--------------------------	----------	--------------------------	------------------	--------------------------

Issued By:	Signed	Date
Engr. Haydar Theabb - Project Manager	<i>Jadine</i>	25-5-2022
Received By	Signed	Date


Please return us one copy of transmittal duly signed




**Material Submittal**

Project Name: G+1 Al Kheesa Souq ( CENTRO MALL )	Submittal Reference No. : AKS-DSG-AEMC-MT-EL-022	Rev00
Client: M.HAI Mana Group	Date : 05-JUNE-2022	
Consultant: DSG	Contractor: K & H Sons of Al Mana Co.	

Submitted by: Engr. **ISMAIL CHOKOR**  
Electrical Project Manager

Signature: 


Date: 5-Jun-22

RECEIVED BY:  5-Jun-22  
STRUCTURAL, MECHANICAL, ELECTRICAL SUPERVISION ENGINEERING

Noted by: Engr. **AHMED EL GAZZAR**  
Contractor's Representative

Signature: 

Date: 5-Jun-22

RECEIVED BY:  5-Jun-22

Material Description: **FLEXIBLE CABLES**

Name of Manufacturer : **SEASHORE CABLES**

Name of Supplier / Local Agent : SEASHORE CABLES FACTORY, ZONE-81,BUILDING 161, STREET 24, P.O BOX : 41116, NEW INDUSTRIAL AREA.  
DOHA, QATAR : TEL : 44888499 FAX :33242127

Area of Application :

Discipline Involved:  Architectural  Structural  Mechanical  Electrical  Interior Design  Others

Approved  Revise and Resubmit  Additional Info. Required  
 Approved as Noted  Rejected  Others

Consultant's Comments :

Refer to the consultant Engineers Comment sheet  
— (RTCA) —

Commented by: **A. Chammas** Name  Signature Date: 8/6/2022  
**Wassim** Consultant Representative  Signature Date:

Client's Comments (if applicable) :

Client Representative: \_\_\_\_\_ Name \_\_\_\_\_ Signature \_\_\_\_\_ Date \_\_\_\_\_

Received by : \_\_\_\_\_  
 Contractor: \_\_\_\_\_ Name \_\_\_\_\_ Signature \_\_\_\_\_ Date \_\_\_\_\_

**RECEIVED**  
09 JUN 2022



دي اس جي للاستشارات المعمارية والهندسية WLL

# Consultant Engineer's Comment Sheet

Project Name	: THE CENTRO MALL @ AL KHEESA	Date	: 08-Jun-22
Client	: Mohammed Hamad Al Mana Real Estate Holdings	PMSD Proj. Ref. No.	: SPN 277
Contractor	: K&H SONS OF AL MANA CO./ AMS	Contract Project Ref.	: GP-19213
Type of Document to which comments are made	: MATERIAL SUBMITTALS	Document Ref. No.	: AKS-DSG-AEMC-MT-EL-022 R0
Discipline:	<input type="checkbox"/> Architectural <input type="checkbox"/> Structural <input type="checkbox"/> Mechanical <input checked="" type="checkbox"/> ELECTRICAL <input type="checkbox"/> Interior Design		
Subject	: FLEXIBLE CABLES - SEASHORE	Submittal Reference	: AKS-DSG-AEMC-MT-EL-022- R0

## Consultant's Comment

### ELECTRICAL COMMENTS


1. Type, size and No. of cores of cables shall be as per approved kahramaa single line diagram and approved shop drawings.
2. Warranty certificate to be submitted along delivery.
3. Derating factors of cables shall be considered in the final cable sizing.
4. Installation, testing and commissioning for cables should as per project specifications requirements, regulations and to the full satisfaction of the Engineer/Consultant.

Discipline:	Architectural	Structural	Mechanical	Electrical	Interior Design
Inspector's Name				ANTOINE CHAMMAS	
Inspector's Signature					
Time				8:00AM	
Date					

Senior Engineer/Project Manager  
(Signature over Printed Name)

8/6/2022

MZP Department Director

<b>PROJECT: MODIFICATION OF EXISTING (G+4) BUILDING (C) AT AL AHLI HOSPITAL, BIN OMRAN</b>		Date: 19-JUNE-2022
		Ref. AGI-MAS-UA-MT-22-23 R2
<b>CLIENT:</b> 	<b>CONSULTANT:</b> 	<b>CONTRACTOR:</b> 
<b>MATERIAL APPROVAL REQUEST</b>		
<b>RECEIVED</b> 		

**We request shop Drawings approval for the following items**

<b>Submittals</b> <input type="checkbox"/> New Submittal <input type="checkbox"/> Resubmittal 1 <input checked="" type="checkbox"/> Resubmittal 2 <input type="checkbox"/> Resubmittal 3 <input type="checkbox"/> Resubmittal 4	<b>Categories</b> <input type="checkbox"/> Architectural <input type="checkbox"/> Structural <input type="checkbox"/> Mechanical <input checked="" type="checkbox"/> Electrical <input type="checkbox"/> Others	<table border="1" style="width:100%; border-collapse: collapse;"> <tr><td><b>Location</b></td><td>AL AHLI HOSPITAL</td></tr> <tr><td><b>Zone</b></td><td>HOSPITAL BUILDING</td></tr> <tr><td><b>Block</b></td><td>C</td></tr> <tr><td><b>Building</b></td><td>NEW ADDITIONAL BUILDING</td></tr> <tr><td><b>Floor</b></td><td>ALL</td></tr> <tr><td><b>Axes</b></td><td></td></tr> </table>	<b>Location</b>	AL AHLI HOSPITAL	<b>Zone</b>	HOSPITAL BUILDING	<b>Block</b>	C	<b>Building</b>	NEW ADDITIONAL BUILDING	<b>Floor</b>	ALL	<b>Axes</b>	
<b>Location</b>	AL AHLI HOSPITAL													
<b>Zone</b>	HOSPITAL BUILDING													
<b>Block</b>	C													
<b>Building</b>	NEW ADDITIONAL BUILDING													
<b>Floor</b>	ALL													
<b>Axes</b>														

**The material submitted for approval has been checked for conformity with drawings and specifications and any deviations noted herein:**

Material Description:	WIRES				
Type of Material:	WIRES				
Drawing Reference	ELECTRICAL DRAWINGS				
Specification Clause					
Fixing Location:	ALL FLOORS				
Technical Literature Attached	YES	<input checked="" type="checkbox"/>	NO	<input type="checkbox"/>	
Sample Attached	YES	<input type="checkbox"/>	NO	<input checked="" type="checkbox"/>	
Compliance Sheet Attached	YES	<input checked="" type="checkbox"/>	NO	<input type="checkbox"/>	
Manufacturer:	M CABLES			 <input type="checkbox"/> Approved <input checked="" type="checkbox"/> Approved as noted <input type="checkbox"/> Revise/resubmit <input type="checkbox"/> Sample Required <input type="checkbox"/> Tests Required <input type="checkbox"/> Additional Information Required <input type="checkbox"/> Manufacturer's Guarantee Required	
Country of Origin:	QATAR				
Local Agent:	M CABLES				
Type of Shipment	Land	<input checked="" type="checkbox"/>	Sea		<input type="checkbox"/>
Anticipated Period of delivery from placing order	READY PRIOR TO CONSULTANT INSPECTION APPROVAL				
Anticipated period when material to be used on site:	IMMEDIATELY AFTER DELIVERY APPROVAL				

**Contractor's Representative: Eng. Alaa Ezzat** Date: 19-JUNE-2022

*Signature* Signature:

**Remarks, Comments:**  
 → Based on attached Vendor list & QCS Compliance Statement, no objection in using "M Cables" for small power wires, provided the size and type of wire shall be as per approved drawing & Mahabna regulation.

<b>Status</b>	A: Approved <input type="checkbox"/>	AAN: Approved As Noted <input checked="" type="checkbox"/>	RR: Revise, Resubmit <input type="checkbox"/>	CA: Conditional <input type="checkbox"/>
	NAR: Not Approved, Resubmit <input type="checkbox"/>	R: Rejected <input type="checkbox"/>	NFD: Need Further Detail <input type="checkbox"/>	N: Noted <input type="checkbox"/>
<b>Engineer</b>	Received by: .....	Date: .....	Signature: .....	
<b>Contractor</b>	Received by: .....	Date: .....	Signature: .....	

**RECEIVED**  
19 JUN 2022  
3.01

Project Logo: 	Project Name: <b>ALYASMEEN CITY - ALWADI 2</b>	Project No.: <b>P15</b>	Form No.:
Client: 	Project Manager: 	Consultant: 	Contractor: 

### MATERIAL APPROVAL REQUEST (MAR)

Submittal Contents: <input type="checkbox"/> - Material/Sample <input type="checkbox"/> - Mock-up <input type="checkbox"/> - Catalogue/Brochure <input type="checkbox"/> - others	MAR No.: <b>P15-SC-CEC-MAR-ELE-001</b> Rev. <b>0</b>
	Date Submitted: <b>21-Jun-2022</b>

Trade / Discipline: <input type="checkbox"/> - Civil <input type="checkbox"/> - Architectural <input checked="" type="checkbox"/> - Electrical <input type="checkbox"/> - Information Tech. (IT) <input type="checkbox"/> - Structural <input type="checkbox"/> - Mechanical <input type="checkbox"/> - Plumbing <input type="checkbox"/> - Others <input type="checkbox"/> - Landscape <input type="checkbox"/> - Interior Design	Date Required on Site: <b>June-22</b> Production Period: <b>TBA</b> Total Delivery Time: <b>June-22</b> Expected Arrival on Site: <b>June-22</b>
---	---

**Description of Material / Equipment:**  
**Wires and Flexible Cables**

---



---



---

**References:**

a.) Specs. Ref. : <u>Section 21, Part 06</u>	c.) QCS 2014 Ref. : <u>Section 21, Part 06</u>
b.) Drawing Ref. : <u>STR Package</u>	d.) Statutory Req. : <u>N/A</u>
e.) BOQ Ref. : <u>Bill 02 - Concrete work</u>	e.) Specified Vendors List <u>Non</u>
Others : _____	

**Manufacturer / Supplier Details:**  - Locally Manufactured  - Imported Country of Origin: **QATAR**

a.) Local Supplier / Agent: Company Name: <b>Seashore Cables Factory</b> Address / Contacts: <b>PO Box: 41116 Tel: 44888499 E: info@seashorecables.com</b>	b.) Manufacturer: Company Name: <b>Seashore Cables Factory</b> Address / Contacts: <b>PO Box: 41116 Tel: 44888499 E: info@seashorecables.com</b>
--	--

Does Material has defined the life cycle and method of disposal as per ISO 14001:2015  - YES  - NO  - Not Applicable

Prepared by: (Contractors PE or CM) <b>Mr. Mohamed Taher</b> Name / Sign / Date	Verified by: (Contractors QA/QC, QS, or Proj. Coordinator) <b>Eng. Mohammad Asif</b> Name / Sign / Date	Recommended for Approval by: (Contractor's PM) <b>Eng. Ahmed Mustafa</b> Name / Sign / Date
---	---	---

**COMMENTS BY THE CONSULTANT**

1. approval in here for wires is limited to 10mm size ,PVC insulation and rated voltage 450/750V only, as provided technical data sheet and compliance statement.
2. No technical detail submitted for multi core cables sizing more than 10mm to showing cable construction insulation voltage and rated current.
3. factory test for each drum to be provided along with material deliver.
4. Provide physical sample before procuring the material for all sizes
5. Size ,type, no. of cores, rating of cables to be used shall be as per approved shop drawing and calculation for voltage drop

(Use a separate comments sheet when necessary, for easy traceability purposes do not forget to include the MAR No., Revision No., & corresponding date of this MAR to the comments sheet.)

**Submittal Status:**  
 - A - Approved  B - Approved as Noted  - C - Revise and Resubmit  - D - Rejected

Supervision Consultant Signature: <b>H. Ali</b> Name & Signature <b>RE or Senior Engineer</b> <b>2/07/2022</b> Designation Date	Client Approval / Endorsement (when required): <b>Belal Hekran</b> Name & Signature <b>Project Manager</b> Designation Date
---	---

Approval or comments to the submittals does not relieve the Contractor from their responsibilities. The assessment is to review the general conformance and compliance of the submittal to the contract and specification requirements.





**MATERIAL SUBMITTAL**

Date : 22-Oct-22  
 Project Name : Al Waab City Central District Phase 1 Package 4 (Parcel 1 & 2)  
 Project No. : J047  
 Client : AL Waab City

NEW SUBMITTAL  RESUBMITTAL  Rev. 01  
 Submittal No. **J047-P4-DM-MS-E-0007**  
 Area of Application: For Normal lighting,AHU,FCU and water heater equipment

**DESCRIPTION**  
**Flexible Cable - Heat Resistant**

Drawing Ref. Q15055-0100D-TD-2-Ha-EL-1.GR.01 Rev. 3  
 Specs. Ref.: Section 21 Part 6 and QCS 2014 sec 21 Part 6  
 BOQ Ref. Bill No 21, Electrical services

Attachment  Compliance Statement  Literature  Test Certificates  Samples

**MANUFACTURER/SUPPLIER / COUNTRY OF ORIGIN**

Supplier Name: Seashore Cables Factory  
 Address: Zone 81, Building 161. Street 24, P.O.Box- 41116, New Industrial Area, Doha-Qatar  
 Manufacturer Name: Seashore Cables Factory  
 Country of origin: Qatar Telephone No.: +974 77715650 , +97444888499



**DELIVERY**

**AVAILABILITY**  
 Locally Manufactured   
 CCASG Manufactured   
 Overseas   
**MANUFACTURE**  
 Production Period   
 Delivery Ex. Works   
 Total Delivery Time

**MODE OF TRANSPORT**  
 Overland   
 Air Freight   
 Sea Freight   
**PROGRAMME**  
 Latest Date for Order   
 Date Material Required



The Contractor certifies that the submitted items have been reviewed in detail and are correct and in strict conformance with the Contract documents except as otherwise stated.  
 For the Contractor

TONY YAGHMOUR  
 Name, Signature

Date:

**CONSULTANT COMMENTS**

(A) Approved  (B) Approved as Noted  (C) Revise & Re-submit  (D) Rejected

**REMARKS**

- No objection for proposed Heat resistant Cable subject To  
 1- Cable size shall not be less than main wire size of circuit  
 2- material shall be delivered in good condition  
 3- Test Certificate shall be provided at the time of material delivery

*[Signature]*  
 26/10/22

CEG Signature

HILL Signature

AWC Signature

Date:

Date: 1-11-22

Date:

Approval by the Consultant and / or the Customer shall not relieve the Contractor of his obligation under the Contract, and the Contractor shall be solely responsible for the soundness and correctness of the submitted documents.



## TRANSMITTAL SHEET

Project Name: <b>Al-Wa'ab City Project, Central District, Phase 1 (Package 4)</b>	Project No :21020
Customer/Owner: <b>Al- Wa'ab City</b>	Date: 02 <sup>st</sup> November 2022
To: Domopan Qatar W.L.L.	From: CEG International
Attention: Mr. Tony Yagmour (Project Manager)	Transmittal No.: P4/CEG/DQ/0434

Please find attached herewith:

Item	Description	Revision	No. of Originals	No. of Photocopies	Paper Size																		
1	<b>Material Submittal</b> <u>Flexible cable – Heat Resistant</u>	01	1		A0																		
<p>(J047-P4-DM-MS-E-0007)</p> <div style="border: 1px solid black; padding: 5px; width: fit-content; margin: auto;"> <p>RECEIVED BY</p> <p>03 NOV 2022</p> <p>DOMOPAN QATAR W.L.L.</p> <p>AL WA'AB CITY PHASE 1 - P4</p> <p><input type="checkbox"/> HAND <input checked="" type="checkbox"/> FAX <input type="checkbox"/> email</p> </div>																							
<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td colspan="2" style="text-align: center;">As Requested</td> <td colspan="2" style="text-align: center;">For Tender</td> <td colspan="2" style="text-align: center;">For Information</td> </tr> <tr> <td colspan="2" style="text-align: center;">For approval</td> <td colspan="2" style="text-align: center;">For Construction</td> <td colspan="2" style="text-align: center;">Customer/Owner's Copy</td> </tr> <tr> <td colspan="2" style="text-align: center;">For Review</td> <td colspan="2" style="text-align: center;">For Fabrication</td> <td colspan="2" style="text-align: center;">Others</td> </tr> </table>						As Requested		For Tender		For Information		For approval		For Construction		Customer/Owner's Copy		For Review		For Fabrication		Others	
As Requested		For Tender		For Information																			
For approval		For Construction		Customer/Owner's Copy																			
For Review		For Fabrication		Others																			
<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td colspan="2" style="text-align: center;">Received by / Date:</td> </tr> </table>						Received by / Date:																	
Received by / Date:																							

DOMOPAN QATAR W.L.L.	
AL WA'AB CITY PHASE 1 - P4	
DATE	SERIAL NO
03/11/22	
DISTRIBUTION	ACTION
H.O	
ED	
PM	
CM	
COM	
ENG	
TECH. CORE	
MEP	
PLAN	
QA/QC	
H.O	
ADM	
LOGISTICS	
OTHERS	
FILE NO.	

Approval by the Consultant and / or the Customer shall not relieve the Contractor of his obligation under the Contract, and the Contractor shall be solely responsible for the soundness and correctness of the submitted documents.



البنك التجاري  
COMMERCIAL BANK



SALAM Industries  
السلام  
مصانع

LOCATION: CBQ CBFS D-RING MEZZANINE BRANCH

MATERIAL APPROVAL REQUEST (MAR)

<b>Project Name</b>	<b>From : SALAM INDUSTRIES</b>	<b>MAR No. 1423-MME-MAR-EL-0006 Rev 00</b>
<b>Fitout at CBQ CBFS D-Ring Mezzanine Branch</b>	<b>To : AL-KASHAF INTERNATIONAL</b>	<b>Date Submitted : 24-01-2023</b>

**Submittal Contents**

Material / Sample
  Catalogue / Brochure
  Others

**Trade / Discipline**

Structural & Architectural
  Fire Fighting
  Electrical  
 HVAC
  Plumbing
  Fire Alarm

**Submission Description**

**Material Submittal for PVC WIRES & CABLES**

**Manufacture / Supplier Details**

Local Supplier / Agent	Manufacture	Country of Origin
SEASHORE CABLES	SEASHORE CABLES	QATAR

**CONTRACTOR'S REVIEW**

Prepared by : Eng. Anandhu R. Name / Sign / Date	Recommended for Approval by : (Contractor's PM) Eng. Subash Name / Sign / Date	Stamp
--	--	-------



NOTE: We certify that the document submitted herewith have been reviewed in details and are in strict conformance with the contract documents, drawings and specifications except as other wise stated.

**COMMENTS BY THE CONSULTANT**

**SUBMITTAL REVIEW STATUS**

- The proposed brand is no technical objection.
- Size of cable/ wire should be as per approved shop drawings.
- Provide test report from manufacturer upon material delivery to site.
- Installation of cables and wires should be as per Kahramaa regulation.
- Flexible Heat resistant cable shall be used 90deg Centigrade temperature rating.
- Installation of cable should be considered the minimum bending radius as per Kahramaa regulation.

APPROVED  
 APPROVED AS NOTED  
 REVISE AND RESUBMIT  
 REJECTED

**SUPERVISION CONSULTANT'S SIGNATURE**

For & On behalf of AL-KASHAF INTERNATIONAL

Eng. \_\_\_\_\_  
Name / Sign  
Date

**Jonathan G. Velicario**





1023-4 Giardino Village 22 Residential Villas (G+2+PH) Plot 101-105  
The Pearl



**MATERIAL APPROVAL SUBMITTAL**

<b>To:</b> TRUST ENGINEERING CONSULTANCY	<b>Date:</b> 25-Jul-23
<b>Attention to:</b> Engr. Mohamed Naguib	<b>Ref. No:</b> 1023-4-MS-EL-2023-02
<b>Designation:</b> Project Manager	<b>Rev. No:</b> 00
<b>Client:</b> Mr. Hamad Ali Hamad Alramoul Almanai	
<b>Contractor:</b> Pride Projects W.L.L.	

**MATERIAL DESCRIPTION :** SINGLE CORE WIRE  
**NAME | TYPE OF MATERIAL:** PVC INSULATED SINGLE CORE ELECTRICAL WIRE  
**AREA | LOCATION IN THE WORKS:**

**MANUFACTURER'S/SUPPLIER'S NAME AND ADDRESS:**  
Name: SEASHORE CABLES FACTORY email: [info@seashorecables.com](mailto:info@seashorecables.com)  
Address: ZONE 81, BUILDING 161, STREET 24, NEW INDUSTRIAL AREA, DOHA, QATAR Phone: +974 444888499  
Contact Person: Mr. Shibil Abubakker Fax: +974 44361248

**MIN-CONTRACTOR'S NAME AND ADDRESS:** website: [www.prideprojects.qa](http://www.prideprojects.qa)  
Name: Pride Projects W.L.L. email: [info@prideprojects.qa](mailto:info@prideprojects.qa)  
Address: Al Naser Tower A, Floor No.19, Office No: 1902, West Bay, Doha, Qatar Phone: +974 40410100  
Contact Person: Engr. Hossam Dahab / Project Manager Fax: +974 44180972

Delivery: YES  
Country of Origin: Qatar  
Availability: YES Locally  Overseas   
Estimated time for delivery on site: 2 WEEKS

**DOCUMENTS ENCLOSED:**  
Sample / Prototype  Spec. Ref.:  
Technical Documents   
Tests  Dwg. Ref.:  
Certificates   
Others

The above submitted material has been checked for conformance with drawings and specifications for this project any deviations from plans and specifications have been noted on the material or listed in the remarks above.

Prepared & Submitted by: Pride Projects WLL Engr. Hussam Almansour / Electrical Manager		Received by: Trust Engineering Consultancy RECEIVED BY: <i>Nasra Asari</i> DOCUMENT CONTROLLER TEC - QATAR BRANCH
Signature: _____ Date: _____		Signature: _____ Date: 26 July 2023

**CONSULTANT'S NOTE/S AND COMMENTS:**  
No objection with the make/brand of the proposed cables and wires (SEASHORE CABLES-QATAR) however, contractor to comply with the following:  
1. Provide compliance statement with project spec. & QCS requirements.  
2. Provide KHM certificates approval .  
3. Contractor is responsible to ensure to verify and confirm that the sizes of the cables are properly sized in accordance to the final electrical load they will serve including the allowable voltage drop as required by Kahramaa Regulation .  
4. Provide and attach the copy of the voltage drop calculation prior to approving the proposed sizes of the cables.  
5. The warranty certificate to be according to project spec.  
6. Method statement for installation to be submitted for review & approval.

Legends: APP  (Approved)      AAN  (Approved as Noted / with Comments)      R&R  (Revise & Resubmit)      RE  (Rejected)

Note\*\* The contractor might proceed to order the material if the status (APP or AAN ) in compliance of the notes

<b>REVIEWED BY Trust Engineering Consultancy</b> Name: _____ Designation: _____ Date: _____ Signature: _____	<b>For:</b> Project Manager: _____ Name: Engr. Gamal Abbas Date: 07-08-2023 Signature: _____	<b>RETURNED TO: Pride Projects WLL</b> Name: mel Date: 07-08-2023 Monday Signature: 7:38pm
--	--	---

**Accepted by: Client**  
Name: \_\_\_\_\_ Signature: \_\_\_\_\_ Date: \_\_\_\_\_



1023-4 Giardino Village 22 Residential Villas (G+2+PH)  
Plot 101-105

SUB-CONTRACTOR APPROVAL SUBMITTAL



To "CONSULTANT": TRUST ENGINEERING CONSULTANCY Date: 25-Jul-23  
 Attention to: Engr. Mohamed Abdelradi Ref. No: 1023-4-PRE-EL-2023-02  
 Designation: Project Manager Rev. No: 00  
 "Client": Mr. Hamad Ali Hamad Alramoul Almannal  
 "CONTRACTOR": Pride Projects WLL

**SUPPLIER'S IDENTIFICATION:**  
 Name: SEASHORE CABLES FACTORY Tel: +974 44888499  
 Address: ZONE 81, BUILDING 161, STREET 24, NEW INDUSTRIAL AREA, DOHA, QATAR Fax: +974 44361248  
 Contract Person: Mr. Shibil Abubakker E-mail: [info@seashorecables.com](mailto:info@seashorecables.com)  
 Designation: Sales Representative Nos of Employees:

**SUPPLIER'S SCOPE / PRODUCTS**  
 Description: Supplier PVC INSULATED SINGLE CORE ELECTRICAL WIRE Comply with vendor list  
 Yes  No   
 Starting Date: Completion Date of Scope  
 Scope of Work/s:  
 Supplier PVC INSULATED SINGLE CORE ELECTRICAL WIRE Percentage from the Total Contract Amount:

**SUB-CONTRACTOR'S ORGANIZATION ON SITE:**  
 Project Manager: Site Engineer:  
 Nos of Manpower in Site: Others (Please Specify):

Documents Attached:

Prequalification of SEASHORE CABLES FACTORY

Note/s:



**SUBMITTED & PREPARED BY PRIDE PROJECTS W.L.L.**  
 Name: Engr. Hussam Almansour - Electrical Manager  
 Signature:   
 Date: 25-07-23

**RECEIVED BY TRUST ENGINEERING CONSULTANCY**  
 Name: RECEIVED BY:   
 Signature: Nasra Asari  
 Date: 26 July 2023 DOCUMENT CONTROLLER  
 TEC - CHIBBI BRANCH

**CONSULTANT'S NOTE/S AND COMMENTS:**  
 1. No objection to the proposed Supplier (SEASHORE CABLES-QATAR) for pvc insulated single core electrical wire  
 2. This per-qualification approval is applicable only to the offered make/brand of material  
 3. This approval is not automatically approved the offered material. Contractor to submit the required material submittal for review and approval

APP  AAN  R&R  Re   
 Legends: (Approved) (Approved as Noted / with Comments) Revise & Resubmit Rejected

**REVIEWED BY TRUST ENGINEERING CONSULTANCY**  
 Name:   
 Designation: For: Project Manager:  
 Name: Engr. Gamal Abbas  
 Date: 07-08-2023  
 Signature: 07-08-2023

**RETURNED TO: PRIDE PROJECTS WLL**  
 Name: mel  
 Date: 07-08-2023  
 Signature: Monday 7:38pm

**ACCEPTED BY "EMPLOYER/CLIENT"**  
 Name: Signature: Date:

<b>Client</b>  FOR PROJECTS & DEVELOPMENT	<b>Consultant</b>  مكتب المهندس عدنان سقاريني معماريون ومهندسون استشاريون <b>Eng. Adnan Saffarini Office</b> Architects & Engineering Consultants	<b>Contractor</b>  FOR PROJECTS & DEVELOPMENT
--	---	--

<b>Material Submittal</b>	<b>Project: Al Waab Apartment Projects</b>
---------------------------	--

Ref. No.: ABK-EAS-AW-MAR-ELE-0043-R0

We request your approval on the following materials

BOQ Ref.	Drawing ref.	Specs. Ref.
----------	--------------	-------------

<input type="checkbox"/> <b>Structural</b>	<input type="checkbox"/> <b>Architectural</b>	<input checked="" type="checkbox"/> <b>Electrical</b>	<input type="checkbox"/> <b>Mechanical</b>	<input type="checkbox"/> <b>Others</b>
<input type="checkbox"/> Earth material <input type="checkbox"/> Forms/ reinforcement <input type="checkbox"/> concrete items <input type="checkbox"/> Steel structure <input type="checkbox"/> Block/ plaster <input type="checkbox"/> Waterproof.	<input type="checkbox"/> Cladding material <input type="checkbox"/> Paint/ ceiling <input type="checkbox"/> Tiles/ marble <input type="checkbox"/> Windows/ Doors <input type="checkbox"/> Joinery <input type="checkbox"/> Metal	<input checked="" type="checkbox"/> Wiring/ cables/ DB's <input type="checkbox"/> Panels <input type="checkbox"/> Wiring devices <input type="checkbox"/> Light fittings <input type="checkbox"/> Generator <input type="checkbox"/> Other equipment	<input type="checkbox"/> Pipes <input type="checkbox"/> Pumps <input type="checkbox"/> Ducting material <input type="checkbox"/> Heaters <input type="checkbox"/> A/C's <input type="checkbox"/> Other equipment	

No.	Details of material	Country of origin	Specs./ BOQ/ dwgs. Reference	Manufactural/ Supplies	serial no.
1	Material Submittal for Flexible cable 4C*1.5sqmm	QATAR		Seashore	

**Attachment:**

<input type="checkbox"/> Samples	<input checked="" type="checkbox"/> Data Sheet	<input checked="" type="checkbox"/> Catalogue	<input type="checkbox"/> Drawings	<input type="checkbox"/> Warranty/ guarantee
<input checked="" type="checkbox"/> Compliance sheet	<input checked="" type="checkbox"/> Certificate of origin	<input checked="" type="checkbox"/> Manual	<input type="checkbox"/>	<input type="checkbox"/>

We hereby certify this submittal data has been reviewed and approved prior to submission and the information contained within has been checked and coordinated with other related requirements.

<b>Contractor Representative</b>		<b>Received by Consultant</b>	
Name	Eng. Ali Mahdi	Name	Eng. Adnan Saffarini
Sign	Projects Director	Sign	
Date/ time	10-Oct-2023	Date/ time	10/10/2023
Stamp		Stamp	

**Consultant's Reply & Comments**

<input type="checkbox"/> A-Approved	<input checked="" type="checkbox"/> AN-Approved as Noted	<input type="checkbox"/> CA-Conditional approval
<input type="checkbox"/> RR-Revise & Resubmit	<input type="checkbox"/> R-Rejected	<input type="checkbox"/> O-Others

- Seashore brand for flexible cable is acceptable .
- The approval is limited for 1.5 mm as per submittal and rated voltage 450/750 V
- The cable size ,no of core ,quantity and temperature rating shall be as per final approved shop drawings .
- The Packing list, bill of lading, certificate of origin, test certificates... etc. to be provided along with delivery and material shall be inspected prior start installation at site .
- Final approval subject to kharmaa inspection approval and project handing over .

<b>Consultant's Representative</b>		<b>Received by Contractor</b>	
Name	Yasser Mohammed	Name	
Sign		Sign	
Date/ time		Date/ time	
Stamp		Stamp	

**PROJECT NAME: AL WAAB APARTMENT PROJECTS**

**Material Submittal Check List**

Submittal Reference No. : ABK-EAS-AW-MAR-ELE-0043 Revision : 0

Discipline : Struct.  Arch.  Mech.  Elec. Date : 10-Oct-2023

Previous Submittal Reference No. : \_\_\_\_\_

Previous Status : \_\_\_\_\_

**Description of Items Submitted:**

MATERIAL DESCRIPTION : Flexible cable 4C\*1.5sqmm

Manufacturer/Supplier Name: Seashore

**Description of the Document:**

	Attached	
	Complied	Remark
1. Material Description & Technical Data Sheet	✓	
2. Project Specification Compliance Statement	✓	
3. Highlighted Specification		
4. Highlighted IFC Drawings		
5. ISO Certificates	✓	
6. Original catalogue and data sheets for proposed manufacturer	✓	
7. Method Statement		
8. Country of Origin Certificate	✓	
9. Commercial Licenses of Suppliers	✓	
10. Project References	✓	
11. Test Certificates	✓	
12. Warranty / Guarantee Certificate	✓	
13. Sample	✓	

**Notes:**

- 1- Each point to be covered if applicable.
- 2- Your Submittal shall be well organized.
- 3- Every section shall be separated with color/number separator paper.
- 4- All the sections to be included in the index page .


التاريخ: 2023/12/12

20370/2023  
20172/2023

السادة/ وزارة الأوقاف والشؤون الإسلامية ،،، إدارة الشؤون الهندسية .. قسم الانشاءات المحترمين

السلام عليكم ورحمة الله وبركاته ... وبعد

المشروع/ بناء مسجد فروض و بيت إمام على أ.د 1099 بمنطقة أم السنين

الموضوع / طلب اعتماد مواد بناء

أما بعد

إشارة إلى الموضوع الموضح أعلاه، بالإشارة إلى الموضوع أعلاه ، تجدون مرفقا طلب اعتماد مواد بناء خاصة  
بالمشروع .

إن اهتمامكم الكريم ومراجعتكم له أهمية كبيرة بالنسبة لنا.


شكرا لدعمكم المتواصل.

تفضلوا بقبول فائق الاحترام والتقدير،

شركة تورن كي للتجارة والمقاولات

المرفقات :

Sr. No.	Reference No.	Description
1	1099-AWQAF-TTC-MAR-ELEC-004	Building Wires & Flexible Cables



Approved  
with comments



Material Submittal		طلب اعتماد مواد بناء
Date: / /	12-Dec-23	/ /
Ref. No. :	1099-AWQAF-TTC-MAR-ELEC-004	
Project :	1099 - Proposed Mosque & Imam House in Um Al Saneem	
Location :	Um Al Saneem	
Owner :	AWQAF	
Start Date / /		/ /
Finish Date / /		/ /

مدة التسليم Del. Period	الوكيل المحلي Local Agent	بلد المنشأ Origin	رقم البند Item Ref.	وصف مواد البناء/ التشطيب Material Description	م No.
	Seashore Cable Factory	Qatar		Building Wire & Flexible Cables	

معلومات المرفقة/ Enclosed Informations

عينات Samples

رسومات Shop Drawings

معلومات مكتوبة Literature

Consultant's Remarks

ملاحظات الاستشاري

مطلوب تسليم عينة Sample Required	<input type="checkbox"/>	يعتمد مع الملاحظات Approved with Notes	<input checked="" type="checkbox"/>	يعتمد Approved	<input type="checkbox"/>
مطلوب معلومات اضافية Information Required	<input type="checkbox"/>	مرفوض Rejected	<input type="checkbox"/>	اعادة التسليم Revise&Resubmit	<input type="checkbox"/>

For internal use only.

ختم وتوقيع المقاول  
Contractor's Stamp & Signature

توقيع الاستشاري  
Consultant's Signal

التاريخ/Date

12/Dec/2023

التاريخ/Date

28/12/23

Distribution

- Original: ✓ Engineer's Rep
- Copies: ✓ Contractor
- ✓ Project Coordinator
- ✓ Project File

- ✓ اصل: ممثل المهندس / مدير المشروع .
- ✓ نسخ: المقاول .
- ✓ منسق المشروع .
- ✓ ملف المشروع .



طلب اعتماد مواد بناء

Material Submittal

Date: / /	20-Apr-24	/ /	:	تاريخ الطلب
Ref. No. :	754-AWQAF-TTC-MAR-ELEC-002		:	رقم الطلب
Project :	754 - Construction Mosque & Imam House in AL EBB		:	اسم المشروع
Location :	AL EBB		:	الموقع
Owner :	AWQAF		:	المالك/ المتبرع
Start Date / /		/ /	:	تاريخ بدء المشروع
Finish Date / /		/ /	:	تاريخ انتهاء المشروع

مدة التسليم Del. Period	الوكيل المحلي Local Agent	بلد المنشأ Origin	رقم البند Item Ref.	وصف مواد البناء/ التشطيب Material Description	م No.
	Seashore Cable Factory	Qatar		Building Wires & Flexible Cables	

المعلومات المرفقة/ Enclosed Informations

عينات Samples

رسومات Shop Drawings

معلومات مكتوبة Literature

Consultant's Remarks

ملاحظات الاستشاري

مطلوب تسليم عينة Sample Required	<input type="checkbox"/>	يعتمد مع الملاحظات Approved with Notes	<input checked="" type="checkbox"/>	يعتمد Approved	<input type="checkbox"/>
مطلوب معلومات إضافية Information Required	<input type="checkbox"/>	مرفوض Rejected	<input type="checkbox"/>	إعادة التسليم Revise & Resubmit	<input type="checkbox"/>

Final Approval subject to KM Approval

ختم وتوقيع المقاول  
Contractor's Stamp & Signature

توقيع الاستشاري  
Consultant's Signature

التاريخ/Date

20/Apr/2024

التاريخ/Date

2024/7/3

Distribution

- Original: ✓ Engineer's Rep
- Copies: ✓ Contractor
- ✓ Project Coordinator
- ✓ Project File

- الاصل: ✓ ممثل المهندس / مدير المشروع .
- النسخ: ✓ المقاول .
- ✓ منسق المشروع .
- ✓ ملف المشروع .

The Employer <b>SHK MOHAMED ABDULRAHMAN J A AL-THANI</b>	The Engineer  <b>LACASA</b> Architects & Engineering Consultants	The Contractor  <b>UCC</b> UrbaCon Trading & Contracting أورباكون للتجارة والمقاولات
---	---	---

**Project Name:** PRIVATE VILLA (G+1+STAIRS) SERVICES BLOCKS & GUARD ROOM AND OUTDOOR SWIMMING POOL IN AL WUKAIR ON PLOT NO. 91012492

## MATERIAL APPROVAL SUBMITTAL

Date: 24-October-2024	Reference: UCC967-LCQ-MAR-ELEC-013	Rev.01
-----------------------	------------------------------------	--------

Material Description: **HEAT RESISTANT FLEXIBLE CABLES**

Model Number, Brand Or Code Of Proposed Material: <b>SEASHORE</b> <b>HEAT RESISTANT FLEXIBLE CABLES</b>	<input type="checkbox"/> Refer to the Attached Summary of Proposed Materials
--	--


Location Of Use:  
 Attachments:  Catalog  Samples  Test Certificate  Other

Specification Section:

Manufacturer Details	Supplier Details
Name : SEASHORE	Name : LIYA ELECTRICAL
Country of origin : QATAR	Country & City : Qatar
Address : BARWA VILLAGE SHOP NO: 39, BUILDING NO: 8	Address : BARWA VILLAGE SHOP NO: 39, BUILDING NO: 8
Agent Telephone : 44377907	Agent Telephone : 44377907



1. Compliance statement should be included in the submittal.
2. Copy of the Contract Specification Section should be included in the submittal
3. All sheets must be signed & sealed by the Contractor and the Specialist Subcontractor(s)
4. Submittal reference number should be noted on the attachments



Submitted By: The Sub-Contractor Representative: Name & Signature:  Mr. Abdul Adil	Submitted By: The Contractor Representative: Name & Signature:  Mr. Nithin Kumar Devadiga Date: 24-Oct-2024
--	--

**THE ENGINEER COMMENTS:**

→ Refer to attached commented sheet.

**ACTION: (As Marked)**

Approved    
 Approved as Noted    
 Not Approved    
 Resubmit


Reviewed By: 	For The Engineer: 	For The Employer: (When Applicable)
--	--	--

**CONSTRUCTION OF PRIVATE VILLA G+1 AND SERVICE BLOCKS AT AI  
Wukair**

Reference No. : UCC967-LCQ-MAR-ELE-013 Rev.01.  
Document Name : Material Submittal.  
Material description : Heat Resistant Flexible Cables.  
Main Contractor : Urbacon Trading and Contracting.  
Comments Date : Oct.26.2024.

Action: Approved As Noted:

- **The Proposed brand "Seashore" is not in the vendor list but No Objection for the proposed brand as per the Client approval.**
- **Selection of Cables size, No of Cores and type shall be as per Approved DB Schedule & Approved Shop drawing.**
- **Specify the area of use for the Heat Resistance cables.**
- **Heat Resistance cables shall not replace the fire rated cables.**
- **All cables sizes and routing shall be as per approved shop drawings.**
- **The Warranty Shall be 2 Years from the date of handing over of the project not from the date of delivery.**
- **Test certificate to be provided upon each delivery of the materials**

<b>Sajid Ur Rehman</b>	<b>Majd Abdulkareem</b>
Electrical Engineer	Project Manager
 26/10/2024	

To "CONSULTANT": **TRUST ENGINEERING CONSULTANCY** Date: 12/9/2024  
 Attention to: ARCH. AHMED HASSAN Ref. No: 979-MAT-ELE-001 R2  
 Designation: PROJECT MANAGER Rev. No: 01  
 "EMPLOYER": SHEIKH NAYF SUHAIM H A AL-THANI  
 "CONTRACTOR": **SPACEDGE DECORATION**

**MATERIAL DESCRIPTION :** CABLES  
**NAME | TYPE OF MATERIAL:** SINGLE CORE WIRE 2.5MM AND 4MM  
**AREA | LOCATION IN THE WORKS:**


**MANUFACTURER'S NAME AND ADDRESS:**  
 Name: SEASHORE CABLE FACTORY  
 Address: DOHA, QATAR Phone:  
 Contact Person: Fax

**SUPPLIER'S NAME AND ADDRESS:**  
 Name: AL ANABI TRADING  
 Address: NAJMA DOHA, QATAR Phone: 71083584  
 Contact Person MR. MURALI Fax: 44303829

Delivery: PARTIAL  
 Country of Orig QATAR  
 Availability: EX STOCK Locally  Overseas   
 Estimated time for delivery on s ONE WEEK

**DOCUMENTS ENCLOSED:**  
 Sample / Prototype  Spec. Ref.:   
 Technical Documents   
 Tests  Dwg. Ref.: قطر - الدوحة - 9923 - ص.ب: 96923 - دoha - قطر  
 Certificates   
 Others

The above submitted material has been checked for conformance with drawings and specifications for this project  
 any deviations from plans and specifications have been noted on the material or listed in the remarks above.

Prepared & Submitted by: "CONTRACTOR" Received by: "CONSULTANT"  
 Representative / Project Engineer: ENG. MOUAAZ SAAD  
 Signature:  Date: 12/9/2024  
 Signature:  Date:  
 RECEIVED By LORENA at 10:55 am, Dec 15, 2024

**CEG'S NOTE/S AND COMMENTS:**  
 The above submitted material has been checked for conformance with drawings and specifications for this project  
 any deviations from plans and specifications have been noted on the material or listed in the remarks above.

SUBMITTAL REVIEW STATUS	RESPONSE CODE						
	(A)	(B)	(C)	(D)	(E)	(F)	(R)
APPROVED AS-NOTED							
REVISE & RESUBMIT							
REJECTED							
MORE INFO. REQUIRED							
FOR INFO ONLY							
REVIEWED AS-NOTED (REPLY)							

Legends: **AP**  (Approved) **AAN**  (Approved as Noted / with Comments) **R&R**  (Revise & Resubmit) **RI**  (Rejected)

**CONSULTANT'S NOTE/S AND COMMENTS:**  
 ACCEPTED SUBJECT TO :  
 1- CONTRACTOR SHALL BE RESPONSIBLE FOR KHM & QCDD REQUIREMENTS & REGULATIONS ON THE INSTALLATIONS.  
 2- FINAL APPROVAL AFTER TESTING , COMMISSIONING AND KHM FINAL APPROVAL.

Legends: **AP**  (Approved) **AAN**  (Approved as Noted / with Comments) **R&R**  (Revise & Resubmit) **RI**  (Rejected)

Note\*\* The contractor might proceed to order the material if the status (APP or AAN ) in compliance of the notes

**REVIEWED BY "CONSULTANT"** **RETURNED TO: "CONTRACTOR"**  
 Name: Engr. M. Tobgy Project Manager: Arch. Ahmed Hassan  
 Designation: Date: Signature:   
 Date: Signature:  
 Signature:

**Accepted by: "EMPLOYER/ENGINEER"**  
 Name: Signature: Date:



Hany Tawfik Consulting Office

### DOCUMENT SUBMITTAL

### MATERIAL SUBMITTAL

Submittal No.	: GV60&GV61-MAT-EL-2025-12	Rev 00	Date	10-Apr-25
Project Name	: GV 60 & GV 61 (B+G+1+PH) Giardino Village The Pearl			
Owner	: Danaat Qatar			
Consultant	: HTCO - Hany Tawfik Consulting Office			
Contractor	: Pride Projects			



Subcontractor/ Supplier	: M/s JMT Contracting	MANUFACTURER: Seashore Cable Factory
		SUPPLIER : ARABELLA TRADING

Prepared by		Rev and App by	
	Engr. MOSTAFA FAWZI Electrical Engineer		Engr Alaa Said -Project Manager

Submittal for	: <input type="checkbox"/> Approval <input type="checkbox"/> Information <input type="checkbox"/> As Requested
Discipline	: <input type="checkbox"/> CIVIL <input type="checkbox"/> ARCH. <input type="checkbox"/> STR. <input type="checkbox"/> MECH. <input checked="" type="checkbox"/> ELEC. <input type="checkbox"/> INSTR. <input type="checkbox"/> Others

#### TYPE OF SUBMITTAL

<input type="checkbox"/> Data sheet (DTS)	<input type="checkbox"/> Forms/ checklist (FRC)	<input type="checkbox"/> Program & schedule (PGS)
<input type="checkbox"/> Design calculation (DEC)	<input type="checkbox"/> Inspection & Test Plan (ITP)	<input type="checkbox"/> Project Quality Plan (PQP)
<input type="checkbox"/> Design Drawing (DWG)	<input checked="" type="checkbox"/> Materials (MAT)	<input type="checkbox"/> Reports (RPT)
<input type="checkbox"/> As-Built Drawings (ABD)	<input type="checkbox"/> Method Statement (MST)	<input type="checkbox"/> Test Result / Certificates (TRC)
<input type="checkbox"/> Sketch (SKT)	<input type="checkbox"/> Organization Chart/CV (OCV)	<input type="checkbox"/> Other (OTH)
<input type="checkbox"/> Shop Drawing (SHD)	<input type="checkbox"/> Pre-Qualification (QFN)	

#### SUBMITTAL DESCRIPTION

SEASHORE CABLES

#### SUBMITTAL STATUS

<input type="checkbox"/> A Approved	<input checked="" type="checkbox"/> B Approved with comments	<input type="checkbox"/> C Revise & Resubmit	<input type="checkbox"/> D Rejected	<input type="checkbox"/> U In Review	<input type="checkbox"/> N Noted
-------------------------------------	--	--	-------------------------------------	--------------------------------------	----------------------------------

#### DECLARATION (IF APPROVED)

This is to certify that this submission has been verified & found in compliance with contract requirements.

#### CONSULTANT'S COMMENTS / RECOMMENDATIONS

1. No objection for Sea Shore cables as Brand.
2. Sizes of the wiring and cables shall be as per the approved SLD by KAHRAMAA.
3. Subject to the KM final approval hand over
4. Mechanical load approval (modification) in order to finalize the size of the cable.
5. The submittal is excluding the fire rated cables and armored cables, contractor to confirm.
6. The Warranty certificate shall be provided form the hand over.
7. The ISO certificate 9001, 14001 and 45001 are expired and shall be updated prior to deliver any material at site.

Reviewed by	Name :	Sign. :	Date : 23/4/25
Approved by	Name :	Sign. :	Date :

Approval by Consultants/Client shall not relieve the Contractor from this obligations under the Contract, the Contractor shall be solely responsible for the soundness and correctness of the submitted materials and/or documents.

## RECEIVED

By Ed at 11:01 am, Apr 23, 2025

16-04-25  
  
Ver 0 - 18 Nov. 20